

**FAIRYVIEW  
HUNTSVILLE  
WATER SUMMARY  
2015  
REPORT**



**DRINKING WATER WORKS PERMIT: 143-203**  
**MUNICIPAL DRINKING WATER LICENCE: 143-103**

**M.O.E. WATERWORKS#: 220002093**

## **INTRODUCTION**

The Fairyview Water Treatment Plant (W.T.P.) is owned and operated by the District of Muskoka. The plant serving the Town of Huntsville, was constructed in 1988. The treatment process consists of chemically assisted coagulation-flocculation, sedimentation, filtration, disinfection by chlorination and pH adjustment. There are reservoirs located at the water treatment plant, Dufferin Street, Skyline Drive and Hanes Road. The Fairyview WTP has a rated capacity of 9,000 cubic meters per day (m<sup>3</sup>/day) and the water system currently serves a population of approximately 9,000 people.

In 2011 the plant operated under Certificate of Approval # 9148-869Q5H Issued June 17, 2010. In addition, in October, 2015 the plant was issued license 143-103 and permit 143-203 under the Municipal Drinking Water Licensing Program. The plant also presently operates under MOE Permit To Take Water # 01-P-1091, which permits the operation of up to 22,500 m<sup>3</sup>/day.

The water source is Fairy Lake, a fairly large and clear body of water. The intake is located in 15 metres of water, about 280 metres from shore.

## **Legislation Requirements**

### **Safe Drinking Water Act**

In the Part Two Report of the Walkerton Inquiry, Commissioner Dennis O'Connor recommended that the Ontario Government enact a Safe Drinking Water Act to deal with matters related to treatment and distribution of drinking water. The Safe Drinking Water Act received royal assent in December, 2002.

The purpose of the Act is to gather in one place all legislation and regulations relating to the treatment and distribution of drinking water. The Act serves to protect human health through the control and regulation of drinking water systems and drinking water testing.

The foundation provisions of the Safe Drinking Water Act include:

- Purpose of the Act
- Definitions
- Minister's Powers and Duties
- Inspections
- Compliance and Enforcement
- Appeals and Offences

### **Ontario Regulations**

The Ontario Government has enacted several supporting regulations under the Safe Drinking Water Act (2000) SDWA. These regulations combine previous requirements under the Ontario Water Resources Act and the new requirements under the SDWA. Key components of the regulations include:

- System Categories

- Groundwater Under Direct Influence Of Surface Water (GUDI)
- Exemptions
- Approval of Systems
- Treatment
- Testing and Operational Checks (General Rules)
- Operational Checks
- Microbiological Testing
- Chemical Testing
- Adverse Conditions
- Corrective Action
- Engineer's and Summary Reports

### Municipal Drinking Water Licenses / Certificates of Approval

The Municipal Drinking Water Licensing Program has replaced the Certificate of Approval program for municipal residential drinking water systems. The Ontario Government has implemented the Municipal Drinking Water Licensing Program (MDWLP) as recommended by Justice O'Connor in the Part II Report of the Walkerton Inquiry. Justice O'Connor recommended a new approvals framework for municipal drinking water systems, which would require owners to obtain a license to operate their systems as well as incorporate the concept of quality management into their operations.

A municipal drinking water license is an approval that is issued by the MOE to owners under the Safe Drinking Water Act, 2002 for the operation of municipal residential drinking water systems. The District of Muskoka operated under various Certificates of Approval until October 2010 when the operating licenses were issued, these have since been renewed on 5 year intervals..

Previous Certificates of Approval were required for the establishment, replacement or alteration of all municipal drinking water systems. The Ministry of Environment (MOE) issued Certificates of Approval to ensure that all undertakings comply with the legislation (i.e. Acts and Regulations) and the Ministry's Environmental Guidelines and Procedures developed to provide consistency of approach to various aspects of environmental protection throughout the province.

Municipal Drinking Water Licenses and Permits similar to previous Certificates of Approval provide specific details about the drinking water system including:

Drinking Water System Description

Definitions and Information

General Information – Compliance, Other Legal Requirements, Adverse Affects, Inspections

Performance – Rated Capacity, Management of Residue

Monitoring and Recording – Flow Measuring Devices, Sampling

Operations and Maintenance

## **Comparison to Rated Capacity and Flow Rate**

The Fairyview Water Treatment plant has a rated capacity of 9,000 m<sup>3</sup>/day. In 2015, the total monthly average flow for the year was 3,254 m<sup>3</sup>/day, which represents 36.2% of the plant's design capacity. The maximum day flow for the year was 4,631 m<sup>3</sup>/day, however, the 3 year average for maximum day flow is 5,440 m<sup>3</sup>/day, which represents 60% of the plant design capacity. (No problems have been associated with this flow).

Monthly flows are shown in the attached table.

The Permit To Take Water (PTTW #01-P-1091) permits 22,500 m<sup>3</sup> /day, therefore there were no exceedances of this permit.

## **Summary of Analytical Results**

A total of 936 microbiological regulatory tests were performed in 2015. There were 524 free chlorine residual tests performed in the distribution system and all results were satisfactory. Response was carried out for all adverse results by proper notification and corrective actions.

A summary of other analytical results is also shown in this report.

## **Summary of Treatment Chemicals**

The following chemicals are used for the treatment of drinking water at the Fairyview Water Treatment Plant:

Chlorine: Disinfectant

Polyaluminum Chloride (SternPAC): Primary coagulant

Soda Ash: Alkalinity and pH adjustment

## **Documentation of System Repairs and Upgrades**

No major upgrades were performed in 2015.

## **External Audits**

### **MOE Inspection**

A MOE inspection was completed on August 6, 2015 and is attached to this report. The overall rating was 100%.

### **DWQMS Audit**

In 2015 all drinking water systems had an external recertification audit performed. There were seven (7) minor non-conformances reported, all have subsequently been addressed and as a result all drinking water systems have been recertified. Overall, all drinking water systems are performing satisfactorily.



**OPTIONAL ANNUAL REPORT TEMPLATE**

<b>Drinking-Water System Number:</b>	220002093
<b>Drinking-Water System Name:</b>	Fairyview Water Treatment Plant
<b>Drinking-Water System Owner:</b>	District Municipality of Muskoka
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 01 to December 31, 2015

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p><b>Does your Drinking-Water System serve more than 10,000 people? Yes [X ] No [ ]</b></p> <p><b>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ X ] No [ ]</b></p> <p><b>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</b></p> <table border="1" style="width: 100%;"> <tr> <td>                 District Municipality of Muskoka                  70 Pine Street                  Bracebridge, Ontario                  P1L 1N3                  705-687-6764                  www.muskoka.on.ca             </td> </tr> </table>	District Municipality of Muskoka 70 Pine Street Bracebridge, Ontario P1L 1N3 705-687-6764 www.muskoka.on.ca	<p><b><u>Complete for all other Categories.</u></b></p> <p><b>Number of Designated Facilities served:</b></p> <table border="1" style="width: 100%;"> <tr> <td>N.A.</td> </tr> </table> <p><b>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</b></p> <p><b>Number of Interested Authorities you report to:</b> <table border="1" style="width: 100%;"><tr><td> </td></tr></table></p> <p><b>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</b></p>	N.A.	
District Municipality of Muskoka 70 Pine Street Bracebridge, Ontario P1L 1N3 705-687-6764 www.muskoka.on.ca				
N.A.				

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

**List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
N.A.	

**Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [ ] No [X ]**



**Indicate how you notified system users that your annual report is available, and is free of charge.**

- Public access/notice via the web**
- Public access/notice via Government Office**
- Public access/notice via a newspaper**
- Public access/notice via Public Request**
- Public access/notice via a Public Library**
- Public access/notice via other method** \_\_\_\_\_

**Describe your Drinking-Water System**

The Water Treatment plant serving the Town of Huntsville was constructed in 1988. The treatment process consists of chemically assisted coagulation-flocculation, sedimentation, filtration and disinfection by chlorination and pH adjustment. The capacity of the plant is 9000 cubic meters per day. The water source is Fairy Lake, a fairly large and clear body of water. The intake is located in 15 meters of water, about 280 meters from shore.

**List all water treatment chemicals used over this reporting period**

Chlorine, Polyaluminum Chloride, and Soda Ash

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

<b>Incident Date</b>	<b>Parameter</b>	<b>Result</b>	<b>Unit of Measure</b>	<b>Corrective Action</b>	<b>Corrective Action Date</b>
May 4/15	Turbidity	>1 NTU	NTU	Correct filter control issue	May 4/15
Nov 25/15	Low system pressure	<140 kPa	kPa	Restore system pressure	Nov 25/15
Dec 30/15	Chemically assisted filtration	N/A	N/A	Restore chemical feed	Dec 30/15

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #) cfu/100 mL	Range of Total Coliform Results (min #)-(max #) cfu/100 mL	Number of HPC Samples	Range of HPC Results (min #)-(max #) cfu/100 mL
<b>Raw</b>	52	0	0	0	
<b>Treated</b>	52	0	0	52	0-5
<b>Distribution</b>	294	0	0	88	0-4

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)	Geometric Average
<b>Turbidity</b>	8760	0.04-0.37	0.06
<b>Chlorine</b>	8760	1.2-1.95	1.62
<b>Fluoride</b> (If the DWS provides fluoridation)			

*NOTE: For continuous monitors use 8760 as the number of samples.*

**1**

*NOTE: Record the unit of measure if it is **not** milligrams per litre.  
MDL = Method Detection Limit, NDOG = No Data, Over Grown*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Antimony</b>	Apr 13/15	0.07<MDL	ug/L	No
<b>Arsenic</b>	Apr 13/15	0.2<MDL	ug/L	No
<b>Barium</b>	Apr 13/15	13.3	ug/L	No
<b>Boron</b>	Apr 13/15	5.6	ug/L	No
<b>Cadmium</b>	Apr 13/15	0.009	ug/L	No
<b>Chromium</b>	Apr 13/15	0.23	ug/L	No
<b>*Lead</b>	Apr 13/15	0.05<MDL	ug/L	No
<b>Mercury</b>	Apr 13/15	0.01<MDL	ug/L	No
<b>Selenium</b>	Apr 13/15	1<MDL	ug/L	No
<b>Sodium</b>	Apr 13/15	16.6	mg/L	Yes
<b>Uranium</b>	Apr 13/15	0.003<MDL	ug/L	No
<b>Fluoride</b>	Apr 13/15	0.06<MDL	mg/L	No

Nitrite	Jan 12/15	0.003<MDL	mg/L	No
Nitrate	Jan 12/15	0..192	mg/L	No
Nitrite	Apr 13/15	0.003<MDL	mg/L	No
Nitrate	Apr 13/15	0..261	mg/L	No
Nitrite	July 13/15	0.003<MDL	mg/L	No
Nitrate	July 13/15	0.315	mg/L	No
Nitrite	Oct 13/15	0.003<MDL	mg/L	No
Nitrate	Oct 13/15	0.213	mg/L	No

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

### Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing			
Distribution	4	0.08-0.44ug/L	0

### Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Apr 13/15	0.02<MDL	ug/L	No
Aldicarb	Apr 13/15	0.01<MDL	ug/L	No
Aldrin + Dieldrin	Apr 13/15	0.01<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	Apr 13/15	0.01<MDL	ug/L	No
Azinphos-methyl	Apr 13/15	0.02<MDL	ug/L	No
Bendiocarb	Apr 13/15	0.01<MDL	ug/L	No
Benzene	Apr 13/15	0.32<MDL	ug/L	No
Benzo(a)pyrene	Apr 13/15	0.004<MDL	ug/L	No
Bromoxynil	Apr 13/15	0.33<MDL	ug/L	No
Carbaryl	Apr 13/15	0.01<MDL	ug/L	No
Carbofuran	Apr 13/15	0.01<MDL	ug/L	No
Carbon Tetrachloride	Apr 13/15	0.16<MDL	ug/L	No
Chlordane (Total)	Apr 13/15	0.01<MDL	ug/L	No
Chlorpyrifos	Apr 13/15	0.02<MDL	ug/L	No
Cyanazine	Apr 13/15	0.03<MDL	ug/L	No
Diazinon	Apr 13/15	0.02<MDL	ug/L	No
Dicamba	Apr 13/15	0.20<MDL	ug/L	No
1,2-Dichlorobenzene	Apr 13/15	0.41<MDL	ug/L	No
1,4-Dichlorobenzene	Apr 13/15	0.36<MDL	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Apr 13/15	0.01<MDL	ug/L	No
1,2-Dichloroethane	Apr 13/15	0.35<MDL	ug/L	No





<b>1,1-Dichloroethylene (vinylidene chloride)</b>	Apr 13/15	0.33<MDL	ug/L	No
<b>Dichloromethane</b>	Apr 13/15	0.35<MDL	ug/L	No
<b>2-4 Dichlorophenol</b>	Apr 13/15	0.15<MDL	ug/L	No
<b>2,4-Dichlorophenoxy acetic acid (2,4-D)</b>	Apr 13/15	0.19<MDL	ug/L	No
<b>Diclofop-methyl</b>	Apr 13/15	0.40<MDL	ug/L	No
<b>Dimethoate</b>	Apr 13/15	0.03<MDL	ug/L	No
<b>Dinoseb</b>	Apr 13/15	0.36<MDL	ug/L	No
<b>Diquat</b>	Apr 13/15	1<MDL	ug/L	No
<b>Diuron</b>	Apr 13/15	0.03<MDL	ug/L	No
<b>Glyphosate</b>	Apr 13/15	1<MDL	ug/L	No
<b>Heptachlor + Heptachlor Epoxide</b>	Apr 13/15	0.01<MDL	ug/L	No
<b>Lindane (Total)</b>	Apr 13/15	0.01<MDL	ug/L	No
<b>Malathion</b>	Apr 13/15	0.02<MDL	ug/L	No
<b>Methoxychlor</b>	Apr 13/15	0.01<MDL	ug/L	No
<b>Metolachlor</b>	Apr 13/15	0.01<MDL	ug/L	No
<b>Metribuzin</b>	Apr 13/15	0.02<MDL	ug/L	No
<b>Monochlorobenzene</b>	Apr 13/15	0.30<MDL	ug/L	No
<b>Paraquat</b>	Apr 13/15	1<MDL	ug/L	No
<b>Parathion</b>	Apr 13/15	0.02<MDL	ug/L	No
<b>Pentachlorophenol</b>	Apr 13/15	0.15<MDL	ug/L	No
<b>Phorate</b>	Apr 13/15	0.01<MDL	ug/L	No
<b>Picloram</b>	Apr 13/15	1<MDL	ug/L	No
<b>Polychlorinated Biphenyls(PCB)</b>	Apr 13/15	0.04<MDL	ug/L	No
<b>Prometryn</b>	Apr 13/15	0.03<MDL	ug/L	No
<b>Simazine</b>	Apr 13/15	0.01<MDL	ug/L	No
<b>THM (NOTE: show latest annual average)</b>	Samples Taken: Jan 12/15 Apr 13/15 Jul 13/15 Oct 13/15	48	ug/L	No
<b>Temephos</b>	Apr 13/15	0.01<MDL	ug/L	No
<b>Terbufos</b>	Apr 13/15	0.01<MDL	ug/L	No
<b>Tetrachloroethylene</b>	Apr 13/15	0.35<MDL	ug/L	No
<b>2,3,4,6-Tetrachlorophenol</b>	Apr 13/15	0.20<MDL	ug/L	No
<b>Triallate</b>	Apr 13/15	0.01<MDL	ug/L	No
<b>Trichloroethylene</b>	Apr 13/15	0.44<MDL	ug/L	No
<b>2,4,6-Trichlorophenol</b>	Apr 13/15	0.25<MDL	ug/L	No
<b>2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)</b>	Apr 13/15	0.22<MDL	ug/L	No
<b>Trifluralin</b>	Apr 13/15	0.02<MDL	ug/L	No
<b>Vinyl Chloride</b>	Apr 13/15	0.17<MDL	ug/L	No

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample

## District of Muskoka - Hwy 60 WTP - Huntsville

### 1.0 Water Flow Summary - 2015

Month	Total Monthly (m <sup>3</sup> )	Average Day Flow (m <sup>3</sup> /d)	Maximum Day Flow (m <sup>3</sup> /d)	Minimum Day Flow (m <sup>3</sup> /d)	Comments
January	93,178	3,006	3,657	2,736	
February	83,937	2,998	4,017	2,619	
March	98,442	3,176	3,498	2,973	
April	93,567	3,119	3,410	2,924	
May	111,301	3,590	4,631	2,847	
June	100,225	3,341	4,210	2,808	
July	115,077	3,712	4,589	3,304	
August	114,359	3,689	3,964	3,417	
September	103,230	3,441	3,969	2,945	
October	98,143	3,166	3,704	2,798	
November	88,996	2,967	3,351	2,661	
December	87,037	2,808	3,159	2,574	

Total 1,187,493

Average Day 3,254

Maximum Day 4,631

Minimum Day 2,574

## District of Muskoka - Hwy 60 WTP - Huntsville

### 2.0 Raw Water Monthly Analysis Summary - 2015

Month	Alkalinity	Hardness	pH	Turbidity	True Colour	Temperature	Cond	Langliers Saturation Index	Total Coliform	E-coli	Total Number of samples taken
<i>Parameter</i>	<i>mg/l</i>	<i>mg/l</i>	<i>pH</i>	<i>ntu</i>	<i>tcu</i>	<i>Celcius</i>			<i>CFU/100ml</i>	<i>CFU/100ml</i>	
January	21.0	51.0	6.6	0.8	49	1.4	33.8	-2.4	19	5.0	4
February	26.0	30.0	6.6	0.7	43	0.9	36.98	-2.6	34.0	2.0	4
March	20.8	32.0	6.7	0.6	42	7.1	46.16	-2.3	19.0	0.0	5
April	18.5	21.0	6.3	1.3	45	3.2	41.1	-3.1	214.0	7.0	4
May	17.5	18.0	6.2	1.0	45	5.7	34.7	-3.2	64.0	4.0	4
June	14.8	17.0	6.3	0.6	41	6.9	36.7	-3.1	74.0	5.0	5
July	12.3	19.0	6.4	0.1	43	7.7	40.6	-3.1	17.0	2.0	4
August	13.8	20.0	6.4	0.4	46	8.7	39.7	-3.1	23.0	0.0	5
September	19.5	17.0	6.2	0.4	43	16.3	40.2	-3.5	23.0	6.0	4
October	13.5	22.0	6.8	0.5	35	14.2	42.1	-2.6	94.0	6.0	4
November	16.0	20.0	6.7	0.5	30	7.4	42.1	-2.7	176.0	15.0	5
December	14.7	23.0	6.8	0.1	50	11.6	38.6	-2.5	116.0	10.0	4
Average	17.4	24.2	6.5	0.6	42.7	7.6	39.4	-2.8	72.8	5.2	4

## District of Muskoka - Hwy 60 WTP - Huntsville

### 9.0 Chemical Usage Summary - 2015

Month	Powdered Activated Carbon		CO2		Hydrated Lime		Coagulant	
	Average Dosage mg/L	Total kg	Average Dosage mg/L	Total kg	Average Dosage mg/L	Total kg	Average Dosage mg/L	Total Kg
January	0.0	0.0	0.0	0.0	0.0	0.0	14.5	1,400
February	0.0	0.0	0.0	0.0	0.0	0.0	14.6	1,298
March	0.0	0.0	0.0	0.0	0.0	0.0	14.6	1,516
April	0.0	0.0	0.0	0.0	0.0	0.0	15.4	1,537
May	0.0	0.0	0.0	0.0	0.0	0.0	16.5	1,926
June	0.0	0.0	0.0	0.0	0.0	0.0	16.2	1,708
July	0.0	0.0	0.0	0.0	0.0	0.0	16.0	1,940
August	0.0	0.0	0.0	0.0	0.0	0.0	15.8	1,917
September	0.0	0.0	0.0	0.0	0.0	0.0	15.8	1,733
October	0.0	0.0	0.0	0.0	0.0	0.0	13.5	1,438
November	0.0	0.0	0.0	0.0	0.0	0.0	12.8	1,197
December	0.0	0.0	0.0	0.0	0.0	0.0	13.0	1,188
Average Monthly	0.0	0.0	0.0	0.0	0	0.0	14.9	1566
Total Yearly		0		0		0		18,797

Month	Sodium Hydroxide		Fluoride		Chlorine		Soda Ash	
	Average Dosage mg/L	Total Kg	Average Dosage mg/L	Total kg	Average Dosage mg/L	Total Kg	Average Dosage mg/L	Total Kg
January	0.0	0	0.00	0.0	3.02	281.1	2.57	0.0
February	0.0	0	0.00	0.0	3.06	256.8	2.57	0.0
March	0.0	0	0.00	0.0	3.02	297.2	2.57	0.0
April	0.0	0	0.00	0.0	3.05	285.2	2.70	0.0
May	0.0	0	0.00	0.0	3.57	397.5	4.40	0.0
June	0.0	0	0.00	0.0	3.71	371.7	3.58	0.0
July	0.0	0	0.00	0.0	3.72	427.9	4.03	0.0
August	0.0	0	0.00	0.0	3.74	428.0	4.71	0.0
September	0.0	0	0.00	0.0	3.74	386.6	4.56	0.0
October	0.0	0	0.00	0.0	3.82	375.2	1.72	0.0
November	0.0	0	0.00	0.0	3.71	330.2	0.37	0.0
December	0.0	0	0.00	0.0	3.68	320.0	2.12	0.0
Average Monthly	0.0	0	0.00	0	3.64	369	3	0
Total Yearly		0		0		4,157		0

Month	Potassium Permanganate		Polymer	
	Average Dosage mg/L	Total Kg	Average Dosage mg/L	Total Kg
January	0.0	0	0.0	0
February	0.0	0	0.0	0
March	0.0	0	0.0	0
April	0.0	0	0.0	0
May	0.0	0	0.0	0
June	0.0	0	0.0	0
July	0.0	0	0.0	0
August	0.0	0	0.0	0
September	0.0	0	0.0	0
October	0.0	0	0.0	0
November	0.0	0	0.0	0
December	0.0	0	0.0	0
Average Monthly	0.0	0	0.0	0
Total Yearly		0		0

## **HUNTSVILLE WATER DISTRIBUTION SUMMARY 2015**

### **New Services**

A total of 37 customers connected to existing water services in 2015, 3 of which were installed in 2015.

One 100 mm PVC water service installed by owner's contractor. This service is located at 332 Townline Rd W.

One 50 mm Poly water service installed by owner's contractor. This service is located at 8 Ott Dr.

One 150 mm PVC water service installed by owner's contractor. This service is located at 15 Marsh Rd.

### **New Watermains**

No watermain was replaced in 2015.

Approximately 64 meters of new 150mm water main was installed on Marsh Rd in 2015 by owner's contractor.

### **Broken Watermains**

District staff repaired a total of 4 watermain breaks during 2015. The average cost to repair each water main break was \$8,894.35.

### **Water Service Leaks**

District staff repaired a total of 8 water service leaks during 2015. The average cost to repair each water service leak was \$5,335.25.

### **Frozen Water Mains**

There was one frozen watermain in 2015.

Clubhouse Dr 200 mm PVC

### **Frozen Water Services**

There were a total of 22 frozen water services reported in 2015.

4 water service were insulated the following Summer. The average cost to insulate each water service was \$7,911.06.

### **Water Valve Replacement**

3 new water main valves were installed in 2015.

No water main valves were replaced in 2015.

16 water main valve boxes were repaired in 2015.

### **Curb stops**

A total of 59 curb stops were repaired, raised or lowered in 2015

4 curb stop valves were replaced in 2015.

### **Fire Hydrants**

There were 3 new fire hydrants added to the water system in 2015.

One at 28 Prestwick Dr – Municipal assumed hydrant, two at 15 Marsh RD E – One Municipal assumed hydrant and one privately owned hydrant

One fire hydrant was replaced in 2015.

There are a total of 614 hydrants in Huntsville, 67 of which are privately owned. All hydrants in Huntsville were flushed at least once in 2015.

**Water Meters**

District staff replaced 124 water meters in 2015 under our scheduled meter change out program.

**Air Release Valves**

All water Air-Vacuum Release Valves were inspected in 2015.

**Locates**

District staff addressed 744 locate requests in 2015.

**Ministry of the Environment and  
Climate Change**

Safe Drinking Water  
Branch

Director's Office  
2nd floor  
40 St. Clair Ave West  
Toronto ON M4V 1M2

**Ministère de l'Environnement**

Direction du contrôle de la qualité de l'eau  
potable

Bureau du directeur  
2<sup>e</sup> étage  
40, avenue St. Clair Ouest  
Toronto (Ontario) M4V 1M2



August 20, 2015

The District Municipality of Muskoka  
70 Pine Street  
Bracebridge, Ontario  
P1L 1N3

**Attention:** Mr. Marcus Firman, Director of Water and Wastewater Engineering

**RE: 2015 Drinking Water Inspection Report  
Huntsville (Fairview) Drinking Water System (DWS#220002093)  
Date of MOECC inspection: August 6, 2015**

---

Please find enclosed the Ministry of the Environment and Climate Change's 2015 Inspection Report for the Huntsville (Fairview) Drinking Water System (DWS#220002093), following an inspection of the water treatment plant and distribution system, August 6, 2015.

The primary focus of this inspection was to confirm compliance with Ministry of the Environment and Climate Change legislation and control documents, as well as conformance with Ministry drinking water related policies for the inspection period. The Ministry is implementing a rigorous and comprehensive approach in the inspection of water systems that focuses on the source, treatment, and distribution components as well as water system management practices.

In order to measure individual inspection results, the Ministry has established an inspection compliance risk framework based on the principles of the Inspection, Investigation & Enforcement (II&E) Secretariat and advice of internal and risk experts. The Inspection Summary Rating Record (IRR), included as Appendix D of the inspection report, provides the Ministry, the system Owner and the associated Public Health Units with a summarized quantitative measure of the drinking water system's annual inspection and regulated water quality testing performance. IRR ratings are published (for the previous inspection year) in the Ministry's Chief Drinking Water Inspector's Annual Report. If you have any questions or concerns regarding the rating, please contact Craig Seabrook, Water Program Supervisor, at 705-739-6392.

Section 19 of the Safe Drinking Water Act (Standard of Care) creates a number of obligations for individuals who exercise decision-making authority over municipal drinking water systems. Please be aware that the Ministry has encouraged such individuals, particularly municipal councillors, to take steps to be better informed about the drinking water systems over which they have decision-making authority. These steps could include asking for a copy of this inspection report and a review of its findings. Further information about Section 19 can be found in the Ministry's publication "Taking Care of Your Drinking Water: A guide for members of municipal council" found under the "Resources" tab on the Ministry's Drinking Water Ontario website at [www.ontario.ca/drinkingwater](http://www.ontario.ca/drinkingwater).

If you have any questions or concerns regarding this inspection report, please contact the undersigned at 705-739-6379.

Respectfully,



James Crumbie  
Provincial Officer  
Ministry of the Environment and Climate Change  
Barrie District Office  
(705) 739-6379 (Tel)  
(705) 739-6350 (Fax)  
[James.crumbie@ontario.ca](mailto:James.crumbie@ontario.ca)

CC Mike Mitchell, District of Muskoka (email: [mmitchell@muskoka.on.ca](mailto:mmitchell@muskoka.on.ca))  
Jason Richardson, Chief Operator, District of Muskoka (email: [jrichardson@muskoka.on.ca](mailto:jrichardson@muskoka.on.ca))  
Medical Officer of Health, Simcoe Muskoka District Health Unit  
Barrie District Office File, Ministry of the Environment and Climate Change





**Ontario**

**Ministry of the Environment and Climate Change**

**HUNTSVILLE (FAIRYVIEW) DRINKING WATER SYSTEM**

**Inspection Report**

<b>Site Number:</b>	220002093
<b>Inspection Number:</b>	1-BYLD9
<b>Date of Inspection:</b>	Aug 06, 2015
<b>Inspected By:</b>	James Crumbie

**OWNER INFORMATION:**

**Company Name:** MUSKOKA, THE CORPORATION OF THE DISTRICT MUNICIPALITY OF  
**Street Number:** 70 **Unit Identifier:** District Office  
**Street Name:** PINE St N  
**City:** BRACEBRIDGE  
**Province:** ON **Postal Code:** P1L 1N3

**CONTACT INFORMATION**

---

**Type:** Owner **Name:** Marcus Firman  
**Phone:** (705) 645-6764 x368 **Fax:** (705) 645-7599  
**Email:** mfirmen@muskoka.on.ca  
**Title:** Director of Water and Wastewater Engineering

---

**Type:** Operator **Name:** Andrew Lynch  
**Phone:** (705) 789-1057 **Fax:** (705) 789-7599  
**Email:** alynch@muskoka.on.ca  
**Title:** Chief Operator Lines

---

**Type:** Main Contact **Name:** Mike Mitchell  
**Phone:** (705) 645-6764 x1331 **Fax:** (705) 789-0385  
**Email:** mmitchell@muskoka.on.ca  
**Title:** Manager of Water and Sewer Operations

---

**Type:** Operator **Name:** Jason Richardson  
**Phone:** (705) 789-8491 **Fax:** (705) 789-0385  
**Email:** jrichardson@muskoka.on.ca  
**Title:** Chief Operator Huntsville, Baysville, Port Sydney

---

**INSPECTION DETAILS:**

**Site Name:** HUNTSVILLE (FAIRYVIEW) DRINKING WATER SYSTEM  
**Site Address:** 330 HIGHWAY 60 HWY HUNTSVILLE P1H 1B5  
**County/District:** Huntsville  
**MOECC District/Area Office:** Barrie District  
**Health Unit:** SIMCOE MUSKOKA DISTRICT HEALTH UNIT  
**Conservation Authority:** N/A  
**MNR Office:** N/A  
**Category:** Large Municipal Residential

**Site Number:** 220002093  
**Inspection Type:** Announced  
**Inspection Number:** 1-BYLD9  
**Date of Inspection:** Aug 06, 2015  
**Date of Previous Inspection:** May 07, 2014

## COMPONENTS DESCRIPTION

**Site (Name):** MOE DWS Mapping  
**Type:** DWS Mapping Point                      **Sub Type:**  
**Comments:**  
Not Applicable

**Site (Name):** RAW WATER  
**Type:** Source                                      **Sub Type:** Surface Water  
**Comments:**

The raw water intake facilities, located in Fairy Lake, consist of 380 metres of 600 millimetre inside diameter intake pipe extending from the intake crib structure to the low lift pumping station (LLPS). The crib is comprised of lap joint timber beams that rest on the lake bottom. The piping is polyethylene Series 80 intake pipe. The intake is located at a depth of approximately 15 metres (49 feet).

**Site (Name):** LOW LIFT PUMP FACILITY  
**Type:** Source                                      **Sub Type:** Surface Water  
**Comments:**

Low Lift Pumping Station (LLPS)

The LLPS, located at 335 Highway 60 East, is a concrete block structure with a locking steel door, an electronic entry alarm, a paved drive, and signage indicating "Authorized Personnel Only".

Raw water from the intake structure enters the facility by gravity, passes through two isolation valves, passes the valved (normally closed) intake flushing line from the backwash pumps at the water treatment plant (WTP), enters the screen well and passes through the manual coarse screen (25 mm mesh size) and the automatic traveling screen (9 mm mesh size). The traveling screen is powered by a small electric motor and is equipped with a spray backwash system. The water for the screen cleaning is drawn from the raw water header by a centrifugal pump and the produced waste is captured and directed to the facility drain line which empties back to Fairy Lake.

The screen well is fitted with an unused chlorine diffuser for prechlorination practices if needed.

This well is also the inlet point for the unused backwash waste tank supernatant recycling line from the WTP. This line can be valved to direct supernatant/ backwash tank waste water to either the screen well or the lake.

Water flows from the screen well into the low lift pump well (LLPW). This tank is situated below grade and is fitted with alarmed level sensors. Four (two duty, two standby) vertical turbine low lift pumps (LLP's) are situated above, and draw from, this tank. Each pump has a rated capacity of 52 L/s (litres per second) at 16 m total dynamic head (TDH) and a constant speed drive. In 2013 low lift pump P-0220 was replaced and a fourth low lift pump was added. There is provision for one more pump. The discharge from each pump is equipped with an air relief valve, an on-line pressure sensor and gauge, a check valve, and an automated flow valve before it ties into the common raw water header. The common raw water header is constructed in a loop. It has a raw water sample tap, a pressure gauge, an air relief valve, a gate valve, a magnetic flow meter, a gate valve, an on-line turbidimeter, an on-line

temperature sensor, an on-line pressure transducer, and an automated flow control valve before it exits the building. On the bottom of the loop, there is a manual butterfly valve.

A 178 m long, 500 mm diameter polyethylene raw water feedermain extends from the LLPS, under Highway 60 and into the WTP.

Floor drains reportedly empty to the lowlift overflow which discharges back out into Fairy Lake. Raw water used to clean the screens, leaking from a pump seal or from the sample sink is generally the only substance which would enter the floor drain.

Pump control instrumentation is located on site. LLP starts are triggered by programmed filter water levels and WTP reservoir water levels.

All controls, monitoring and alarms on site are routed through the PLC (Programmable Logic Controller) at the facility and on to the SCADA (Supervisory Control and Data Acquisition) system at the WTP.

The 450 mm drain line which empties to the lake can capture WTP overflow from the flocculation tanks, overflow from the reservoir, washing effluent from the traveling screen, and supernatant on an emergency basis (if recycling and discharge to sanitary sewer are not available).

---

**Site (Name):** TREATED WATER - PART 1

**Type:** Treated Water POE

**Sub Type:** Treatment Facility

**Comments:**

The Huntsville (Fairview) WTP was commissioned in 1988 to produce drinking water by chemically assisted filtration and disinfection practices, and to supply that water to the Town of Huntsville. It is a concrete block facility with a below grade reservoir and contact tanks. It is located at 330 Highway 60 East. It has numerous entries, all of which have electronic entry alarms, a paved drive, an outdoor, locked power transformer station, an on-site sewage pumping station, and posted contact information signage.

**Pre-Treatment Facility**

Raw water from the LLPS enters the WTP through a valved 400mm main. It flows into the 6.7m<sup>3</sup> Soda Ash Mixing Chamber under pressure. Soda ash solution is injected at this point. This tank has an approximate detention time (DT) of one minute. It is equipped with a mechanical mixer, a level sensor, and a sluice gate over which water splits into two trains and flows into the Soda Ash Retention Chambers.

These two parallel 35 m<sup>3</sup> retention chambers are each split into two smaller chambers with sluice gates at inlet and outlet. Mixing results due to manipulation of water flow. They provide a DT of 10 minutes. On-line pH analysers are situated in these tanks. Water flows from these tanks into a common Flash Mix Chamber.

**Rapid Mixing Facility**

Water enters from the bottom of this 6.7 m<sup>3</sup> tank, coagulant (SternPAC) is added and mixed with a ducted mechanical mixer, and flows out the top through a sluice gate. A shelf spare mechanical mixer is on-site.

**Flocculation Facility**

The water splits into two parallel trains before it enters the flocculation tanks through mechanical gates and over a sluice. The flocculation facility consists of four 62 m<sup>3</sup> flocculation tanks constructed in two parallel trains of two tanks in series with emergency overflow provision to Fairy Lake. The trains are equipped with sluice gates to isolate one train or extend one train to consist of three basins. Each tank provides 10 minutes DT and is equipped with a variable speed drive mixer. Water flows from these tanks into the Flocculated Water Channel which can be valved to by-pass the Settling Tanks but typically is not. On-line pH analysers are located in these channels.

**Sedimentation Facility**

The sedimentation facility consists of two 216 m<sup>3</sup> Settling Tanks constructed in parallel. Each tank consists of four modules of plate settlers with a minimum angle of inclination of 55° to provide a 69 minute retention time. The tanks are equipped with an automatic withdrawal system consisting of a suction-type sludge collector. The withdrawal system collects settled sludge and discharges it via gravity to the sewage pumping station. This system is powered by a pneumatic air compressor system.

Water flows from these tanks into the sluice gated Filter Influent Channel.

#### Filtration Facility

The filtration facility consists of two dual media filters (sand/anthracite) in 84 m<sup>3</sup> tanks (Filters 4100 and 4200). Each filter has a surface area of 48 m<sup>2</sup> and a filtration rate of 7.8 m/h (metres per hour). Both filters are equipped with a 305 mm layer of silica sand and an 800 mm layer of anthracite over stainless steel underdrain laterals. The underdrains associated with the filters were replaced in May 2008 (Filter 4100) and June 2009 (Filter 4200). Inlet flow is controlled by motorized sluice gates from an inlet/ backwash channel while backwash discharge enters the same channel with a second set of motorized sluice gates. Each tank has an on-line, alarmed level sensor for LLP control, a pressure differential sensor for head loss monitoring, a sample pump drawing from the effluent line to supply the lab with filtered water samples, pressure transducers, and individual, on-line turbidimeters on the filter effluent lines. Both filters are equipped with on-line magnetic flow meters, and flow control valves monitor and control effluent flow volumes into the Filter Effluent and Backwash Well.

Two (duty and standby) vertical turbine backwash pumps, rated at 260 L/s at 12m TDH, and located in a room adjacent to the filters, draw from the backwash water well and supply water to the bottoms of the filters for backwashing. The emergency intake flushing capability has been removed. The backwash pump discharges are equipped with check valves and gate valves before combining into a common header which splits to each filter and is equipped with an air relief valve, an on-line magnetic flow meter and motorized valves which regulate flow to the respective filters.

During backwashing, one of two (duty and standby) air blowers, rated at 425 L/s, provide air scour to break up heavy materials. The supply lines for the blowers are equipped with mechanical flow valves.

Backwashes are currently manually initiated on each filter, but can be automated. Although piping tees are in place to allow for filter-to-waste capabilities, the tees are flanged and filter-to-waste valving and discharge piping is not yet installed for filter-to-waste to be practiced following the backwash cycles.

---

**Site (Name):** TREATED WATER - PART 2

**Type:** Treated Water POE

**Sub Type:** Treatment Facility

**Comments:**

#### Clearwell System

The clearwell system includes a 363 m<sup>3</sup> Backwash Well constructed to provide contact time for disinfection. Water from the filters is chlorinated at the point of entry to this tank. The backwash water well receives water from the filters, is hydraulically connected to the filter effluent well, and overflows to the reservoir. The joined 242 m<sup>3</sup> filter effluent well provides contact time for disinfection. Water from this well overflows to the reservoir. An on-line free chlorine residual analyser with pH adjustment and a 0-5 mg/L range draws continuous samples from this point by way of a pump.

#### Reservoir System

A 1457 m<sup>3</sup> baffled reservoir provides contact time for disinfection and in-plant storage, with emergency overflow provision to Fairy Lake.

#### High Lift Pumping Station (HLPS)

The HLPS consists of a 1044 m<sup>3</sup> capacity high lift pump well and four (two duty, two standby) vertical turbine high lift pumps (HLP's). Two pumps have a rated capacity of 40 L/s at 78 m TDH and Two pumps have a rated capacity of 140 L/s at 78 m TDH with variable frequency drives.

This tank is equipped with an on-line level sensor, and an on-line free chlorine residual analyser with pH adjustment and a 0-2 mg/L range draws continuous samples from the reservoir, for primary

disinfection monitoring purposes, using centrifugal pump. Each highlift pump discharge is equipped with an on-line pressure sensor and gauge, an air relief valve, a check valve, and a mechanical flow valve before they join into a common discharge header, which is equipped with an unused injection point for fluoride, and a valved flow meter by-pass line. Following this is a pressure relief valve which returns water to the reservoir if system pressure gets too high, the trim chlorine injection point, an on-line magnetic flow meter for finished water flow monitoring, an on-line pressure transducer, a gate valve, the post soda ash injection point for pH adjustment, a pressure transducer, a pressure gauge, and a domestic water supply line with backflow prevention, before water is discharged to Zone 1 of the distribution system.

A supply line draws water from the point it enters the supply water main at Highway 60. This line supplies an on-line free chlorine residual analyser with pH adjustment and a 0-5 mg/L range for finished water, an on-line finished water turbidimeter, a temperature sensor, and a pH analyser.

Floor drains reportedly empty to the sanitary sewers.

Pump and process control instrumentation is located on site.

All controls, monitoring and alarms on site are routed through the PLC on-site and on to the SCADA system at the WTP.

The HLP's are triggered by receipt of programmed low reservoir level signals from the Deerhurst Reservoir, the Hanes Road Reservoir, the Skyline Reservoir, and/or the Dufferin Street Reservoir. The SCADA system monitors and controls all of these sites remotely. Alarms from the above sites are routed through the WTP SCADA system.

#### Standby Power Facility

A 500 kW standby diesel generator with a contained 4,540 L diesel fuel storage tank provides emergency power to critical process equipment. The tank has manual and electronic fuel gauges. The generator is programmed for automatic starts and stops during power outages. There is a capped fill line to the outside and a vent line to the outside.

**Site (Name):** CHEMICAL FEED SYSTEMS

**Type:** Treated Water POE

**Sub Type:** Treatment Facility

**Comments:**

#### Chemical Storage and Feed Systems

The soda ash storage and feed system consists of a 36000 kg storage silo with pressure and level sensors in a below grade and ventilated room, a 425 kg/d (kilogram per day) volumetric dry feeder, a level alarmed mixing tank which is supplied with finished water, a transfer pump, a 350 L solution day tank with level alarms, and two (duty and standby) positive displacement pre-soda ash metering pumps. Each metering pump has a rated capacity of 394 L/h and injects soda ash solution into the Soda Ash Mixing Chamber for pH and alkalinity adjustment. One post-soda ash pump rated at 228 L/hr, replaced in 2013 with a Watson Marlow Peristaltic Hose Pump Mod. Apex 20, with a max flow rate of 350l/hr at a discharge pressure of 95psi, injects soda ash solution in the HLP discharge header for final pH adjustment and corrosion control. A shelf spare pump is available. There is a level alarmed sump pit and pump in the bottom of this chamber which discharges to the sanitary sewers.

The pumps are equipped with backflow prevention, but not failure alarms.

The coagulant storage and feed system consists of two contained 30,000 L solution storage tanks with alarmed ultrasonic level sensors, drain valves, and access hatches, two (duty and standby) positive displacement chemical metering pumps with a rated capacity of 72 L/h and backflow prevention, and chemical feed lines to inject the coagulant (SternPAC) into the Flash Mixing Chamber. The pumps are equipped with flow monitors and failure alarms through SCADA.

The gas chlorine disinfection system consists of two, one tonne cylinder alarmed weigh scales, storage capacity for five one tonne cylinders, two automatic switchover vacuum regulators and automatic chlorine gas feed systems, and three chlorinators (one duty for the filter effluent and backwash water well duty, one duty for the HLP discharge header top up, one standby). Chemical feed lines inject chlorine at two of the following injection points: the low lift pumping well (provisional

pre-chlorination), the Flash Mixing Chamber (provisional chlorination), the filter effluent/backwash water well (duty chlorination), and in the HLP discharge header (top-up chlorination, as needed).

Two in-line positive displacement pumps have been installed where the removed chlorine dioxide system was located. These pumps circulate high pressure finished domestic water past the chlorinators and provide enough pressure to inject this water into the pressure main at the HLP discharge. An alarmed chlorine gas detector is in-place. The chlorination room is separated from rest of the WTP and is separately ventilated.

All chemical feed systems are flow paced and only operate while the WTP is producing water. These systems alarm through, and are monitored and controlled by, the SCADA system.

The hydrofluosilicic acid system equipment remains in place but is no longer being used.

---

**Site (Name):** BACKWASH PROCESS RESIDUALS - TREATMENT AND RE-CIRCULATION

**Type:** Treated Water POE

**Sub Type:** Treatment Facility

**Comments:**

Backwash Process Residuals – Treatment and Re-Circulation System

A two-cell filter backwash holding/settling tank, with a combined volume of 524 m<sup>3</sup> and hopper bottoms, stores filter backwash water and settles out suspended solids. The tank is equipped with an emergency overflow provision to Fairy Lake. Two (one for each cell) self-priming suction lift type supernatant pumps, rated at 11 L/s at 7 m TDH and equipped with float suction, isolation valves, and backflow prevention, are installed to allow for supernatant to be returned to the LLPS for recycling, however this system has never been used, and all wastewater is directed to the sanitary sewers via the on-site sewage pumping station. Emergency discharge provisions of backwash wastewater supernatant is also available to the plant overflow, and out to Fairy Lake, if recycling and sanitary discharge are not available. Two (one for each cell) submersible sludge pumps, rated at 63 L/s at 6.2 m TDH, and with backflow prevention and mechanical flow valves, discharge the settled sludge to the plant sewage pumping station (typical practice).

The two tanks have alarmed level sensors.

The inlet lines from the filters have mechanical flow valves.

Sewage Pumping Station

The sewage pumping station, located in front of the WTP, is equipped with two (duty and standby) submersible pumps, each pump having a rated capacity of 9.9 L/s at 8.7 m TDH, collects all backwash water including supernatant, settled sludge, liquid from floor drains, plant domestic wastewater, generator cooling water, and sump pump discharges and directs it to the sanitary sewer system.

---

**Site (Name):** DISTRIBUTION (WATER INSPECTION)

**Type:** Other

**Sub Type:** Other

**Comments:**

The water distribution system for the community of Huntsville serves a population of approximately 9000 persons. The piping within the distribution system is reported to be composed mostly of PVC watermain with some other types (polyethylene (PE), ductile iron, cast iron). The cast iron pipes are being relined or replaced, depending on main size, regularly. The watermain ranges in diameter from 25 mm to 500 mm with a total estimated installed length of 96 km and approximately 850 main valves, 27 air release valves and 537 fire hydrants (31 privately owned).

There are two rechlorination/ booster stations/ reservoirs located within the distribution system: the Hanes Road facility and the Skyline Reservoir (formerly the Hidden Valley WTP).

There is one reservoir/ booster station: The Dufferin Street Reservoir.

There is one booster station: the Homestead (Settler's Ridge) Booster station.

Two other booster stations, the Highlands Drive Booster and the Deerhurst Residence (Highway 60) Booster, do still exist, however, they are no longer being used and plans for those sites remain under consideration.

The distribution facilities are further described in the following sections.

Based upon July 2015 information, the system incorporates 3381 total services – approximately 2939 residential services, approximately 368 commercial services, approximately 62 institutional services and approximately 12 industrial services.

**Site (Name):** SKYLINE (HIDDEN VALLEY) RESERVOIR, BOOSTER STATION, AND RECHLORINATION FACILITY

**Type:** Other **Sub Type:** Reservoir

**Comments:**

The Skyline (Hidden Valley) Reservoir, Booster Station and Rechlorination Facility, located at 1632 Skyline Drive, consists of a below grade, concrete, two cell clearwell/reservoir approximately 18.3 m by 9.1 m by 5.5 m deep which provides an approximate total volume of 916 m<sup>3</sup> and an electronically alarmed concrete block building with a locking steel door. It is located at a high point in the distribution system.

At a programmed low water level, the facility PLC signals the SCADA system at the WTP to start the HLP's and fill the reservoir. Distribution water from Zone 1 (Grandview) enters the station through a 250 mm inlet line and passes a normally closed gravity outlet line, an isolation valve, an on-line magnetic flow meter for inlet flow monitoring, a flow control valve which regulates inlet flow, a check valve, an on-line pressure transducer, and past an unused chlorine injection point. A sample line supplies an alarmed, on-line continuous free chlorine residual analyser which has pH adjustment and a 0-2 mg/L range from this location. If rechlorination is used, this analyser would trigger (through the PLC and SCADA system) sodium hypochlorite pump starts and stops at programmed free chlorine residual concentrations. Immediately after the chlorine injection point, the inlet line splits into two valved reservoir fill lines. Typically both valves are open and the reservoir cell levels are maintained with an equalization valve between them. The cells can be operated individually if needed.

Both cells are equipped with on-line level sensors, overflow ports which empty outside to the rear of the facility, raised access hatches with plate metal covers and ladders, two vertical turbine pressure pumps, and valved discharge lines which join into a common gravity discharge line.

Two HLP's (duty and standby) rated at 15.1 L/s at 53 m TDH draw from Cell 2, and two HLP's (duty and standby) rated at 15.1 L/s at 33.1 m TDH draw from Cell 1. These pumps direct water to Zone 3 of the distribution system. The discharge of each pump is equipped with backflow prevention, an air relief valve, and an isolation valve before joining to form the common discharge header. The common header is fitted with a pressure relief valve which will automatically open and direct water back into the reservoir cells if system pressure gets too high, an on-line pressure transducer, an on-line magnetic flow meter for monitoring pumped discharge volume, a chlorine injection point, and an alarmed, on-line continuous free chlorine residual analyser which has pH adjustment and a 0-2 mg/L range. Before leaving the facility, this line splits into two valved lines to feed the distribution system.

The pumps at the reservoir start and stop on programmed system pressure readings. They will start and run sequentially as demand increases.

Gravity draws water out of the two cells through a common outlet line. It passes a check valve, the tie in for the Zone 4 gravity by-pass to the inlet line, a valve, an on-line magnetic flow meter for gravity discharge flow monitoring, a valve, and an alarmed, on-line continuous free chlorine residual analyser which has pH adjustment and a 0-2 mg/L range before water leaves the facility to supply Zone 4 of the distribution system and on to the Deerhurst Reservoir.

A currently unused rechlorination system is in place which consists of two contained 100 L sodium hypochlorite day tanks, one on an alarmed, on-line weigh scale, and two alarmed metering pumps (duty and standby) rated at 3.6 L/h. The pumps can be triggered by inlet or outlet water free chlorine residual.



A diesel generator to provide standby power for the booster pumps, chemical feed system, and control equipment has also been installed in a separate room at the facility. It is programmed for automatic starts and stops during power outages. Diesel fuel is stored on site in a contained steel tank with an approximate 900 L capacity, a manual fuel gauge, a capped and locked fill line to the outside and a vent line to the outside.

Contact information signs are posted on site.

There is no gate or fence on the grounds.

Floor drains reportedly empty to the sanitary sewers.

All controls, monitoring and alarms on site are routed through the PLC at the facility and on to the SCADA system at the WTP.

The reservoir vents are screened. One is located inside the building while the second is located outside beside a locked plate metal access hatch.

The below grade pipe gallery is equipped with an automatic sump pump with a check valve on the discharge line. It directs water to the sanitary sewers. The pipe gallery is alarmed for floods.

Backflow preventers are in place on domestic water lines in the facility.

---

**Site (Name):** DUFFERIN STREET RESERVOIR AND BOOSTER STATION

**Type:** Other

**Sub Type:** Reservoir

**Comments:**

The Dufferin Street Reservoir and Booster Station, located at 40 Florence Street, consists of two in-ground, concrete cells with a total approximate volume of 2270 m<sup>3</sup>, a below grade valve chamber, and a concrete block building with two locking steel doors, all within a locked chain link fence compound. All of the doors are equipped with electronic entry alarms and the compound is monitored by video cameras at all times. It is located at the end of a dead-end street at a high point in Huntsville.

Treated water enters the below grade valve chamber from the distribution system via the WTP or other booster stations by way of a common inlet/ gravity outlet line. This chamber is accessed by a locked steel door set in the hillside below the reservoir chambers. The chamber is alarmed for flooding and for entry. The common inlet main splits in two just after it enters the chamber. The smaller, pressure water fill line tees off the common line and is fitted with a continuously monitored pressure transducer and a gate valve. The fill line is fitted with an on-line magnetic flow meter and a flow control valve which acts as a check valve and regulates inlet flow before it splits into two individually valved reservoir cell fill ports.

The straight run of the common inlet/ gravity outlet line is of much larger diameter than the fill line and is fitted with a gate valve for isolation purposes. This line is the gravity drain line. It is fitted with an on-line magnetic flow meter, a second gate valve before it splits into two lines, both equipped with valves and check valves which empty the two reservoir cells from the bottom by gravity. These valves are accessed by way of locked plate steel hatches on the outside top of the reservoir cells. Gravity discharge from this reservoir supplies Zone 1 - Huntsville.

A third locked plate steel hatch next to the valve chamber hatches provides access to the reservoir overflow chamber. Unscreened holes in the sides of both cells empty into a catchment basin which has a drain hole in its base to carry away overflow water to the town storm sewers.

The building on site contains the pumps, the diesel generator, the PLC and control equipment, valves, piping and an on-line free chlorine residual analyser.

Each cell is fitted with individual on-line, alarmed level sensors, isolation valves, and plate metal access hatches with ladders which are elevated above floor level on concrete pads. The cells are approximately 4 m in depth. Typically the water levels in the cells are equalized by a gate valve between them but they can be operated independently.

Three vertical turbine pumps draw from the reservoir cells. Two, rated at 25.2 L/s at 34 m TDH, draw from one cell and one rated at 38 L/s at 32 m TDH draws from the second cell. Each pump discharge is equipped with a check valve, a pressure gauge, an air relief valve, and a gate valve before they

combine into a common discharge pressure header. A line from this header supplies an alarmed, on-line continuous free chlorine residual analyser which has pH adjustment and a 0-2 mg/L range, an on-line, alarmed pressure transducer, and a pressure gauge. The common discharge line is fitted with a pressure relief valve which will automatically open and return water to both reservoir cells if system pressure gets too high. A solenoid valve is also fitted on this line which opens regularly to ensure fresh water is circulated to the reservoir if the pumps do not run regularly.

After the pressure relief valve, there is a gate valve, a tee to a valved line for flow meter by-pass, an on-line magnetic flow meter for pressure flow to Zone 2 of the distribution system, another gate valve, the return line for the flow meter by-pass, and the point of discharge to the distribution system.

The reservoir fills when the facility PLC registers a specific low set point in the cells and signals the SCADA and PLC at the WTP. Filling stops when the cells reach a programmed level and the PLC signals the SCADA at the WTP to shut down the HLP's.

The pumps at the reservoir start and stop on programmed system pressure readings. They will start and run sequentially as demand increases.

A stand-by diesel generator is located in a separate room at the facility. It is rated at 40 kW and is programmed for automatic starts and stops during power outages.

Diesel fuel is stored on site in a contained steel tank with an approximate 500 L capacity, a manual fuel gauge, a capped fill line to the outside and a vent line to the outside.

No Entry and video surveillance signs are posted on site.

Floor drains reportedly empty to the sanitary sewers.

All controls, monitoring and alarms on site are routed through the PLC at the facility and on to the SCADA system at the WTP.

---

**Site (Name):** HOMESTEAD (SETTLER'S RIDGE) BOOSTER

**Type:** Other

**Sub Type:** Booster Station

**Comments:**

The Homestead Lane (Settler's Ridge) Booster station is located within a brick and concrete block building at 824 Muskoka Road 3 North. The building is approximately 6.1 m by 3.7 m with a locking steel door and electronic entry alarms. It is supplied from a water main from Muskoka Road 3 and supplies the Settler's Ridge development of approximately 35 homes on a dead-end line along Homestead Lane and designated as Zone 1A.

Water enters the booster station through a 300 mm stainless steel supply line. This line supplies a pressure gauge, two 100 mm pump inlet lines, one 200 mm pump inlet line, a 100 mm pressure relief return line, an in-line check valve and joins with the discharge line to which the pressure relief valve is joined.

The three pump supply lines are all equipped with isolation valves. The two smaller lines supply identical centrifugal pressure pumps while the large supply line inlets to a larger centrifugal supply pump for a total of three pressure pumps. Water discharged from these pumps passes through individual flow control/check valves, isolation valves and into the common discharge header. The common discharge header splits to return to the inlet header/pressure relief valve, to four valved bladder pressure tanks, and to a magnetic flow meter for monitoring discharge flows. This flow meter is not monitored on-line. The bladder tanks maintain line pressure when the pumps are not operating.

The discharge line is increased to 300 mm and supplies a pressure gauge, four pressure switches for pump control and a sample line.

The floor drains empty into the sanitary sewers.

Pump control is independent of the SCADA system and PLC(s) at the WTP or any other facility with a panel contained within the building.

An outlet is provided for emergency generator hook up.

Alarms generated at this facility are routed through an independent autodialer. There is no signage at this site.

**Site (Name):** HANES RESERVOIR

**Type:** Other

**Sub Type:** Reservoir

**Comments:**

The Hanes Road Reservoir, Rechlorination Facility and Booster Station, located at 10 Hanes Road, consists of two, 1170 m<sup>3</sup> in-ground, concrete cells with a total approximate volume of 2340 m<sup>3</sup>, and a below grade valve and works chamber accessed from the outside with two locking steel doors. There is a locked bar steel gate on the paved access road and a sign with contact information. All of the doors are equipped with electronic entry alarms. It is located at a high point in Huntsville.

Treated water enters the below grade valve and works chamber from the distribution system via the WTP or other booster stations by way of a common inlet/ gravity outlet line. This chamber is accessed by a locked steel door set in the hillside below and in front of the reservoir chambers. The inlet main splits in two just after it enters the chamber. One direction leads to a valve and a pressure relief valve which will automatically open and return water to the inlet line from the pressure discharge line and both reservoir cells if system pressure gets too high. Typically, water is directed in the other direction, towards the reservoir cells. The inlet line is fitted with a valve, a sodium hypochlorite injection point, an on-line magnetic flow meter, an alarmed, on-line continuous free chlorine residual analyser which has pH adjustment and a 0-2 mg/L range, an on-line, alarmed pressure transducer, a flow control valve which acts as a check valve and regulates inlet flow (along with the PLC and pressure transducer), and a check valve before it splits into two individually valved reservoir cell fill lines. Both inlet lines have air relief valves. Rechlorination is currently used. The inlet free chlorine analyser triggers (through the PLC and SCADA system) sodium hypochlorite pump starts and stops at programmed free chlorine residual concentrations.

Both cells are fitted with individual on-line, alarmed level sensors, isolation valves on the discharge lines, and locked plate metal access hatches with raised concrete pads, located outside, above ground on top of the reservoir cells with ladders. Typically the water levels in the cells are equalized by a gate valve between them but they can be operated independently. Venting occurs through the overflow piping.

One valved 300 mm line empties each cell by gravity. The two lines are linked but remain separated so both will supply the pressure discharge and the gravity discharge. A pressure gauge is located at the link. After the link, one line becomes the gravity outlet line. It is fitted with a check valve and an on-line magnetic flow meter before directing water back to Zone 1 – Huntsville.

The second line supplies the four centrifugal pressure pumps for pressure discharge to Zone 2B or if desired, back to Zone 1.

Two pumps rated at 18L/s at 40 m TDH (duty and standby) with variable frequency drives (VFD's), and two pumps rated at 105 L/s at 30 m TDH (duty and standby) are in-place. The pumps at the reservoir start and stop on programmed system pressure readings. They will start and run sequentially as demand increases.

Each pump discharge is equipped with a pressure gauge, a check valve, and a flow control valve before they combine into a common discharge pressure header.

This header has an air relief valve and a line with a solenoid valve which opens regularly to ensure fresh water is circulated to the reservoir if the pumps do not run regularly. The common discharge line ties into the pressure relief /inlet line and the main pressure discharge line to Zone 2B. The discharge line has a chlorine injection point (not in use), an isolation valve, an on-line magnetic flow meter, an alarmed, on-line continuous free chlorine residual analyser which has pH adjustment and a 0-2 mg/L range, an on-line, alarmed pressure transducer which, along with the PLC and SCADA at the WTP,

controls pressure pump operation, an isolation valve and a domestic water line with backflow prevention before it discharges to the distribution system.

The reservoir fills when the facility PLC registers a specific low set point in the cells and signals the SCADA and PLC at the WTP. Filling stops when the cells reach a programmed level and the PLC signals the SCADA at the WTP to shut down the HLP's.

The rechlorination system consists of one contained 100 L sodium hypochlorite day tank on an alarmed, on-line weigh scale and two alarmed metering pumps (duty and standby) rated at 3.6 L/h. The pumps can be triggered by inlet (current practice) or outlet water free chlorine residual.

A stand-by diesel generator is located in a separate room at the facility. It is rated at 125 kW and is programmed for automatic starts and stops during power outages.

Diesel fuel is stored on site in two contained steel tanks with a total approximate 2200 L capacity, manual fuel gauges, electronic fuel gauges, a capped fill line to the outside and a vent line to the outside.

Reservoir overflows are captured in a catch basin within the building and are then directed to a barred culvert discharge point in a rock lined ditch beside the access road.

Floor drains reportedly empty to the sanitary sewers.

All controls, monitoring and alarms on site are routed through the PLC at the facility and on to the SCADA system at the WTP.

This facility was put in service on April 25, 2007.

---

## INSPECTION SUMMARY

### INTRODUCTION

- \* The primary focus of this inspection is to confirm compliance with Ministry of the Environment and Climate Change (MOECC) legislation as well as evaluating conformance with ministry drinking water related policies and guidelines during the inspection period. The ministry utilizes a comprehensive, multi-barrier approach in the inspection of water systems that focuses on the source, treatment and distribution components as well as management practices.

This drinking water system is subject to the legislative requirements of the Safe Drinking Water Act, 2002 (SDWA) and regulations made therein, including Ontario Regulation 170/03, "Drinking Water Systems" (O.Reg. 170/03). This inspection has been conducted pursuant to Section 81 of the SDWA.

This report is based on a "focused" inspection of the system. Although the inspection involved fewer activities than those normally undertaken in a detailed inspection, it contained critical elements required to assess key compliance issues. This system was chosen for a focused inspection because the system's performance met the ministry's criteria, most importantly that there were no deficiencies as identified in O.Reg. 172/03 over the past 3 years. The undertaking of a focused inspection at this drinking water system does not ensure that a similar type of inspection will be conducted at any point in the future.

This inspection report does not suggest that all applicable legislation and regulations were evaluated. It remains the responsibility of the owner to ensure compliance with all applicable legislative and regulatory requirements.

The Huntsville (Fairview) drinking water system serves the Town of Huntsville. Huntsville is the northernmost community in the District Municipality of Muskoka, along Provincial Highway 11. The drinking water system services an estimated population of 9000 persons. There are approximately 3381 total service connections, of which approximately 2939 are residential services; 368 are commercial services; 62 are institutional services, and approximately 12 are industrial services. The Huntsville (Fairview) drinking water system is owned and operated by the Corporation of the District Municipality of Muskoka. The Corporation of the District Municipality of Muskoka is referred to as the Owner, Operator and Municipality for the purposes of this inspection report.

Drinking water for the Huntsville community is obtained from Fairy Lake. The Huntsville (Fairview) drinking water treatment plant was constructed in 1988, with a number of replacements, alterations and upgrades occurring since that time. The drinking water treatment process consists of chemically assisted coagulation-flocculation, sedimentation and filtration using multi-media filters with a combination of silica sand and anthracite coal. Disinfection is achieved by chlorination through the use of chlorine gas. Alkalinity and pH adjustment also occurs during the treatment process and prior to the treated water being conveyed to the distribution system. Historically, drinking water treatment had also included fluoridation, however fluoridation has not been practiced since February 3, 2014, following the passing of By-law No. 2014-2 by the District Municipality of Muskoka Council in January 2014.

The Huntsville (Fairview) drinking water treatment plant is rated to treat up to 9000 cubic meters of water per day.

The drinking water system is comprised of outstations. An outstation is defined as a component of a drinking water system that is not located at either a water treatment plant or well supply and is not associated with primary treatment. The Huntsville(Fairview) drinking water system is comprised of the following six outstations:

## INTRODUCTION

1. Raw Water Intake
2. Low Lift Pump Station
3. Dufferin Street Reservoir and Booster Station
4. Homestead/Settler's Ridge Booster Station
5. Hanes Reservoir, Booster and Rechlorination Station
6. Skyline(Hidden Valley) Reservoir, Booster and Rechlorination Station

The Highlands booster pumping station and the Deerhurst Residence(Highway 60) Booster Station were also formerly outstations associated with the works. However, these stations have both been taken off line.

The Huntsville (Fairyview) drinking water system is categorized as a Large Municipal Residential drinking water system and is regulated by the Safe Drinking Water Act, 2002 (SDWA) and regulations made therein, including Ontario Regulation (O.Reg.)170/03.

Operation of the Huntsville (Fairyview) drinking water system is authorized under Municipal Drinking Water Licence #143-103 (Licence) and Drinking Water Works Permit 143-203 (Permit) which were issued to the District of Muskoka respectively on October 14, 2010 and October 13, 2010. The Licence expires October 13, 2015, and an application has been submitted by the Owner to renew the Licence with the Ministry. This application was made on February 3, 2015, and remains under review.

Water takings from Fairy Lake are permitted in accordance with Permit to Take Water (PTTW)#2801-8FNPSN issued April 12, 2011. The PTTW allows the Owner to take a maximum of 22500000 Litres per day (L/d) from Fairy Lake at a rate not exceeding 16700 Litres per minute (L/min). The PTTW expires on January 15, 2021. Compliance with the PTTW was not assessed during the course of this inspection; however, the Owner is aware that water takings must be done in accordance with the conditions of a valid PTTW.

The Huntsville (Fairyview) Drinking Water System was last inspected by the Ministry on May 7, 2014. Findings associated with that 2014 inspection were detailed in Inspection Report #1-BBVG3, issued to the Owner on June 18, 2014.

The August 6, 2015 inspection, to which this inspection report pertains, encompasses an inspection review period between May 7, 2014 and August 6, 2015, 2015. The August 6, 2015 inspection included a physical inspection of the water treatment equipment and facilities; interviews with operational staff; and a review of relevant documents for the inspection review period. The Low Lift Pump Station; Dufferin Street Reservoir and Booster Station; Hanes Reservoir, Booster and Rechlorination Station; and, the Skyline(Hidden Valley) Reservoir, Booster and Rechlorination Station were also attended during this inspection.

## CAPACITY ASSESSMENT

- \* **There was sufficient monitoring of flow as required by the Permit and Licence or Approval issued under Part V of the SDWA**

Condition 2.1, Schedule C of the Licence requires the Owner to ensure the continuous flow measurement and recording be undertaken for the flow rate and daily volume of water conveyed into the treatment system and the flow rate and daily volume of water conveyed from the treatment system into the distribution system.

To comply with this condition, the Owner has installed a flow meter on the combined raw water discharge header at the low lift pumping station, flow meters on each of the two separate filter train discharges, and one on the plant discharge header entering the distribution system. A flow meter is also installed on the filter backwash line to measure the backwash flow rates and volumes, and flowmeters are installed at each of the reservoir outstations to measure flows both into and out of those facilities.

### CAPACITY ASSESSMENT

Instantaneous flow rates are measured by each flow measuring device and continuously trended and recorded on the Supervisory Control and Data Acquisition (SCADA) system associated with the drinking water system. Totalized daily flows are calculated by SCADA, and transcribed to record keeping mechanisms for reporting purposes. Several of the flow meters are also used for process control purposes.

All flow measuring devices were most recently calibrated on November 4, 2014.

- **The owner was in compliance with the conditions associated with maximum flow rate or the rated capacity conditions in the Permit and Licence or Approval issued under Part V of the SDWA.**

Condition 1.1, Schedule C of the Licence stipulates that the maximum daily volume of treated water that flows from the Huntsville (Fairview) Water Treatment Plant to the distribution system shall not exceed 9000 cubic metres per day (m<sup>3</sup>/day).

In 2014 the maximum day demand occurred on May 29, 2014 when a total daily flow of 4579m<sup>3</sup> or 50% of the rated capacity was noted to have occurred. The average day demand for 2014 was reported to be approximately 3267m<sup>3</sup>/d or 36% of the plant rated capacity.

Between January 1, 2015 and up to the date of this inspection, August 6, 2015, the maximum day demand occurred on May 12, 2015 when a total daily flow of 4631m<sup>3</sup> or 51% of the rated capacity was noted to have occurred. The average day demand for this same period is reported to be approximately 3290m<sup>3</sup>/d or 37% of the plant rated capacity.

During water production the rate of flow into the treatment system is governed by valving installed on each of the filtration trains and low lift pump operation is based on maintaining a sufficient water level in the filters. A review of records made during this inspection review period indicates that the Huntsville (Fairview) drinking water system was not operated to exceed the plant rated capacity set out in the Licence. Similarly, records indicate that the filters were not operated in excess of their design capacities (215m<sup>3</sup>/hr) during the production of water. The filters are typically operated at a filtration rate of 120m<sup>3</sup>/hr in the summer months and 80m<sup>3</sup>/hr during the winter months.

### TREATMENT PROCESSES

- **The owner had ensured that all equipment was installed in accordance with Schedule A and Schedule C of the Drinking Water Works Permit.**

With the exception of the Fluoridation system and both the Deerhurst Residence Highway 60 Booster Pumping Station and the Highlands Pumping Station, all equipment described in the Permit issued October 13, 2010, and supporting documents prepared since that time, appeared to be installed and operating on the date of this inspection. As previously discussed, fluoridation of the Huntsville drinking water system ended on February 3, 2014, and although the fluoridation equipment remains in place it is not being used. Similarly, the Deerhurst Residence Highway 60 Booster Pumping Station and the Highlands Pumping Station are no longer being operated, however the structures and equipment associated with those components remain in place. The two booster pumping stations were no longer considered necessary following the installation of a new watermain in 2012, to service the Deerhurst Resort expansion using the Skyline Reservoir, Booster Station, and Rechlorination facility. Plans to fully decommission the Deerhurst Residence Highway 60 Booster Pumping Station and the Highlands Pumping Station are under consideration.

In addition to those changes, the Owner has also undergone a number of replacements, alterations and upgrades to the works. This has included the replacement of an existing low lift pump, addition of a fourth low lift pump, installation of new pH analysers, the replacement of the venturi flow meter on the high-lift pump discharge header with a magnetic flow meter, the replacement of the filter effluent turbidimeters, and the replacement of the 228L/h post soda ash pump with a 350L/h Watson Marlow Peristaltic Hose Pump. These alterations occurred during the previous inspection review period, and the appropriate Form 2 – Record of Minor Modification documents were reportedly prepared to facilitate the alterations.

**TREATMENT PROCESSES**

During this inspection review period, the Owner replaced the gas chlorinators with new Trent Severn gas chlorine systems, and a Form 2 – Record of Minor Modification form was completed to support this replacement.

There were reportedly no other alterations to the works during this inspection review period, which required the preparation of a Form 2 document. Although several HVAC related upgrades occurred, this work did not necessitate the completion of a Form 3 document and there were reportedly no other additions or alterations made which required the completion of a Form 3 document.

- \* **The owner/operating authority was in compliance with the requirement to prepare Form 1 documents as required by their Drinking Water Works Permit during the inspection period.**

During the inspection review period, the Owner prepared a Form 1 – Record of Watermain Authorized as a Future Alteration document to facilitate the replacement of three watermain valves which occurred in January 2015. There was no concern identified with the content included on the documents. There were reportedly no other watermain additions or modifications undertaken during this inspection review period to necessitate the preparation of any additional Form 1 documents.

- \* **The owner/operating authority was in compliance with the requirement to prepare Form 2 documents as required by their Drinking Water Works Permit during the inspection period.**

During this inspection review period the Owner replaced the gas chlorinators with new Trent Severn gas chlorine systems, and a Form 2 – Record of Minor Modification form was completed to support this replacement. As previously discussed, the Owner has submitted the necessary documents to have the Licence renewed, and as part of that process it is expected that the Permit will be renewed.

- \* **Records indicated that the treatment equipment was operated in a manner that achieved the design capabilities required under Ontario Regulation 170/03 or a Permit, Licence or Approval issued under Part V of the SDWA at all times that water was being supplied to consumers.**

O.Reg.170/03 requires that treatment for a surface water source consist of chemically assisted filtration and disinfection capable of achieving at a minimum 2-log removal or inactivation of *Cryptosporidium* oocysts, a 3-log removal or inactivation of *Giardia* cysts and a 4-log removal or inactivation of viruses.

These requirements are reportedly met by coagulation, clarification and filtration followed by chlorination with chlorine gas for both primary and secondary disinfection purposes.

According to the Ministry's Procedure for Disinfection, the filtration process is credited with 2.5 log *Giardia* cyst removal, 2.0 log *Cryptosporidium* oocyst removal and 2.0 log virus removal credits, if the filtration process meets the following criteria:

- use a chemical coagulant at all times when the treatment plant is in operation;
- monitor and adjust chemical dosages in response to variations in raw water quality;
- maintain effective backwash procedures, including filter-to-waste or an equivalent procedure during filter ripening to ensure that the effluent turbidity requirements are met at all times;
- continuously monitor filtrate turbidity from each filter; and,
- meet the performance criterion for filtered water turbidity of less than or equal to 0.3 NTU in 95% of the measurements each month.

To ensure these criteria are met, the Owner has installed a chemical coagulation system comprised of chemical metering pumps dedicated to each filter train, and each equipped with chemical flow sensors linked to SCADA for alarming purposes. In the event the chemical pumping system fails, the filter inlet and outlet valves closed and the Low Lift pumps shut down such that water production ceases until such time the metering pumps are returned to service.



## TREATMENT PROCESSES

Continuous turbidimeters installed on each filter train are configured to trigger an alarm and lock out the low-lift pumps, should filter effluent turbidity exceed 0.3NTU, or should the turbidity meter register a signal loss/malfunction.

The multimedia filters are configured through SCADA to backwash automatically. Typically the filters are backwashed each day at a prescribed time, however the filters may also be backwashed manually or programmed to backwash based on run time or filter headloss. Formalized filter backwashing procedures are available within the Operations and Maintenance Manual.

The filters do not currently have filter-to-waste capabilities. Following a backwash cycle, the respective filter enters into a five minute rest period prior to the filter effluent valve opening. The filter effluent turbidimeters are continuously supplied with filter effluent from a location downstream of the filter but upstream of the respective filter effluent control valve, such that the turbidimeter is supplied with continuous samples during the backwash rest period. Should the filter effluent turbidity remain above the 0.3NTU alarm set point, at the end of the rest period, the effluent valve will not open and an alarm sequence will be triggered.

Although a filter issue did reportedly occur on May 4, 2015, which resulted in approximately 20 m<sup>3</sup> of filtered water exceeding 1.0NTU being conveyed to the treated water reservoir, continuous monitoring records indicate that the filters were still operated to meet the performance criterion for filtered water turbidity of less than or equal to 0.3 NTU in 95% of the measurements each month during this inspection review period, including the month of May 2015. Records also indicate that the coagulant system was in operation when water was being produced, and backwash procedures were followed during this inspection review period. The May 4, 2015 high turbidity occurrence was the result of a SCADA control issue which occurred during maintenance work. The incident was responded to immediately and was reported to the Ministry and the Simcoe Muskoka District Health Unit immediately as Adverse Water Quality Incident (AWQI)#123465. Additional changes were also made to the SCADA filter backwash controls to ensure similar occurrences are not repeated. There was no indication that the occurrence impacted on the downstream disinfection process.

To achieve the remaining 0.5-log Giardia cysts and 2-log Virus removal or inactivation, a free available chlorine residual chemical disinfection system is utilized and the CT disinfection concept is used to quantify the capability of the disinfection system for primary disinfection purposes. Free available chlorine residual is achieved through the addition of gas chlorine solution. The effective disinfectant contact time required for the CT concept is afforded in the reservoir cells. The treatment system is typically operated to target a free available chlorine residual of 1.0mg/L, throughout the reservoirs and prior to the trim chlorination injection point, where secondary chlorine addition occurs in efforts of increasing the chlorine residual to approximately 1.6mg/L before entering the distribution system. The chlorine residual analyzer used for primary disinfection monitoring purposes is configured to trigger an alarm sequence in the event free chlorine residuals fall below 0.80mg/L. Should the free chlorine residual fall below 0.50mg/L the high-lift pumps will shut down, ceasing water conveyance from the plant until operational staff respond to the site and resolve any issues. The SCADA system is also configured to calculate CT continuously to ensure adequate disinfection is provided and will alarm if CT is not met.

A manual CT calculator is installed on the computer in the control room and is available for operators to verify any occurrence using the worst case scenario values. Supporting documentation related to CT is also available in the operations and maintenance manual.

Records reviewed indicate that the water treatment plant was operated to achieve the necessary CT requirements for primary disinfection purposes during this inspection review period.

- **Records confirmed that the water treatment equipment which provides chlorination or chloramination for secondary disinfection purposes was operated so that at all times and all locations in the distribution system the chlorine residual was never less than 0.05 mg/l free or 0.25 mg/l combined.**

Following completion of the intended chlorine contact time for primary disinfection purposes, trim chlorination is provided to target a free available chlorine residual of 1.6mg/L in the water being

## TREATMENT PROCESSES

conveyed to the distribution system. Trim chlorination is practiced, to allow for the chlorine concentrations through the treatment process to be reduced in efforts of controlling/reducing Trihalomethane formation, and also to ensure that sufficient free available chlorine residual is maintained out and into the distribution system for secondary disinfection purposes in accordance with section 1-5 of Schedule 1, O.Reg.170/03.

The Huntsville (Fairview) water treatment plant is designed to target a free chlorine residual between 1.5 and 1.6 mg/L at the point of entry into the distribution system which should ensure a minimum free chlorine residual of 0.2mg/L is maintained throughout the distribution system as is recommended in the Ministry's Procedure for Disinfection. In addition to the trim chlorination which occurs on the high-lift pump discharge header, re-chlorination facilities also exist at both the Hanes Reservoir and the Skyline Reservoir within the distribution system, however re-chlorination typically only occurs at the Hanes Reservoir. The free chlorine residual concentrations within the distribution system are being measured by continuous analyzers installed at the Skyline Reservoir, Dufferin Reservoir and Hanes Reservoir. In each of these locations analyzers are installed to measure the chlorine residuals in the water conveyed both into and out of these facilities.

A chlorine analyzer installed at the plant is supplied with continuous samples of water from a location within the distribution system approximately 200 metres downstream of the trim chlorine injection point. This analyzer is used to control the trim chlorine injection rate, and is configured to trigger an alarm and shut down the high-lift pumps if the chlorine residual being conveyed from the plant drops below 1.0mg/L.

The distribution chlorine residual analyzers installed at the Hanes Reservoir location are configured to trigger an alarm if the chlorine residual in the incoming water drops below 0.2mg/L and or the chlorine residual in the water being discharged drops below 0.6mg/L.

The analyzers at the Skyline Reservoirs are configured to alarm if the chlorine residual in either the incoming water or the water being pumped falls below 0.4mg/L. The Skyline Reservoir also has an analyzer installed on the gravity discharge line, which is configured to alarm if the chlorine residual drops below 0.3mg/L.

The analyzer installed at the Dufferin Reservoir is configured to alarm if the free chlorine residual falls below 0.4mg/L.

In addition, chlorine residuals are measured during microbiological sampling and maintenance activities throughout the distribution system. System wide hydrant flushing is conducted each spring and dead end hydrant flushing is conducted each fall or in response to any issues.

Records indicate that free chlorine residuals were maintained at or above the 0.2mg/L throughout the distribution system during this inspection review period; and, there were no records which indicated free chlorine residuals less than 0.05 mg/L at any time during the inspection review period. The recorded distribution system free chlorine residual concentrations ranged between 0.20mg/L and 2.2mg/L.

- \* **The Operator-in-Charge had ensured that all equipment used in the processes was monitored, inspected, and evaluated.**

Operators evaluate the system processes at the Fairview water treatment plant daily, Monday through Friday. They verify the operating conditions through SCADA trending and record any departures from normal operating conditions. Weekends and holidays are also considered, to ensure that the review of the continuous monitoring data does not exceed 72 hours in duration. The specific operating conditions are recorded on their checklists and also stored electronically in Excel spreadsheets. Records of the checks are written in the log book at the water treatment plant.

## TREATMENT PROCESS MONITORING

**TREATMENT PROCESS MONITORING**

- **Primary disinfection chlorine monitoring was being conducted at a location approved by Permit, Licence or Approval issued under Part V of the SDWA, or at/near a location where the intended CT had just been achieved.**

The primary disinfection chlorine monitoring point is currently located at the end of the high-lift pump well. A centrifugal pump is used to draw water from the well to supply the analyzer, ensuring that this monitoring is being conducted prior to the trim chlorine injection point, which is situated on the high-lift pump discharge header. The chlorine analyser is situated in the high-lift pump room, and is linked to SCADA for continuous monitoring, trending and alarming purposes, and is used by SCADA and operational staff to calculate CT provisions.

- **Continuous monitoring of each filter effluent line was being performed for turbidity.**

In accordance with subsection 7-3(2)(b) of Schedule 7, O.Reg.170/03 the Owner has installed continuous turbidimeters on each filter train effluent lines. For operational purposes the Owner has also installed continuous turbidimeters for the purpose of measuring the turbidity of the raw water and the finished drinking water conveyed to the distribution system. All four of the turbidimeters are linked to the SCADA system for continuous trending, monitoring and alarm purposes.

The high turbidity alarm set points on the two filter trains is at 0.30 NTU. SCADA is also configured to initiate an alarm should turbidity measure a low analog output (4mA), which might suggest a turbidimeter malfunction. Should either a high or low turbidity alarm condition occur, the filter inlet and outlet valves close, ceasing the production of water. The filter train alarms are present to help ensure compliance with the Procedure for Disinfection of Drinking Water in Ontario effluent turbidity requirements of being less than or equal to 0.30 NTU in 95% of the measurements recorded each month on each filter effluent line.

The turbidimeter installed to measure the treated water is configured to initiate an alarm should treated water turbidity exceed 1.00NTU, and the raw turbidimeter is configured to trigger an alarm if raw water turbidity exceeds 5.00NTU.

- **The secondary disinfectant residual was measured as required for the distribution system.**

The free chlorine residual concentration within the distribution system is being measured by continuous analyzers installed at the Skyline Reservoir, Dufferin Reservoir and Hanes Reservoir. The distribution chlorine residual analyzers are configured to trigger an alarm if chlorine residual drops below the setpoints, previously discussed, at either of the reservoir locations. In addition, chlorine residuals are measured during microbiological sampling and maintenance activities throughout the distribution system.

The recorded distribution system free chlorine residual concentrations ranged between 0.20mg/L and 2.20mg/L, during this inspection review period.

- **Operators were examining continuous monitoring test results and they were examining the results within 72 hours of the test.**

The data review is completed daily Monday through Friday. Weekends and holidays are considered. Operators are scheduled to conduct a data review so that the time between checks does not exceed the 72 hour regulatory requirement.

The weekend results of the continuous monitoring equipment are being reviewed on Mondays, or the day after in the case of a holiday and documented in the log book in order to satisfy Schedule 6, O.Reg.170/03 requirements for examination of continuous monitoring data.

In addition to the regular on-going review of continuous turbidity records, operational staff also reportedly review the filter turbidity measurements at the end of each calendar month to ensure the filter criterion are being met and records of this review are typically made within the record keeping mechanisms.

**TREATMENT PROCESS MONITORING**

- \* **All continuous monitoring equipment utilized for sampling and testing required by O. Reg. 170/03, or approval or order, were equipped with alarms or shut-off mechanisms that satisfied the standards described in Schedule 6.**

Continuous monitors are used to assess primary disinfection chlorine residual concentrations, secondary disinfection chlorine residual concentrations, and turbidity on each filter effluent. At the time of inspection, the analyzer used for primary disinfection monitoring had a low chlorine alarm set point of 0.8mg/L and a low/low chlorine alarm set point of 0.50mg/L. Both the high and high/high chlorine alarm set points were at 2.0mg/L. By activating the low or high setpoints an alarm notification process is initiated and an operator responds to the site. By activating the low/low or high/high alarm, the high-lift pumping capabilities will cease and allow time for an operator to intervene. As previously discussed, an analyzer is also installed to monitor chlorine residuals downstream of the trim chlorine injection point effectively measuring the chlorine residual in the water being conveyed to the distribution system. This analyzer is configured to alarm and shut down the high-lift pumps if chlorine residuals fall below 1.0mg/L or are above 2.60mg/L. Secondary disinfection was monitored in the distribution system at Skyline Reservoir, Dufferin Reservoir and Hanes Reservoir. The distribution chlorine analyzers are configured to trigger an alarm if chlorine residual drops below the setpoints, previously discussed, at either of the reservoir locations.

The filter effluent turbidity high set point alarm was set at 0.30(NTU), and SCADA is configured to alarm if the turbidimeter generates a low analog signal (4mA). Should either the low or high turbidity alarms be triggered, the filter inlet and outlet valves shut down, ceasing the production of water, until rectified.

- \* **Continuous monitoring equipment that was being utilized to fulfill O. Reg. 170/03 requirements was performing tests for the parameters with at least the minimum frequency specified in the Table in Schedule 6 of O. Reg. 170/03 and recording data with the prescribed format.**

Schedule 6 of O.Reg.170/03 outlines the recording frequency requirements for continuous on line analysers. It requires that the free chlorine residual for primary disinfection be tested and recorded with a frequency of every five minutes. Turbidity monitoring must be performed with a minimum frequency of 15 minutes. If secondary disinfection monitoring uses continuous analysers, as is the case for secondary disinfection monitoring conducted at the Reservoirs, the free chlorine residual in a distribution sample must have a minimum recording frequency of 1 hour.

Complying with these requirements, continuous monitoring data is recorded and trended on the SCADA system at five to ten second intervals.

- \* **All continuous analysers were calibrated, maintained, and operated, in accordance with the manufacturer's instructions or the regulation.**

The Huntsville (Fairview) water treatment plant is equipped with continuous analysers for pH, chlorine residual, turbidity, fluoride and temperature. Calibrations are completed a minimum of at least once per month, exceeding the manufacturer's recommendations to ensure effective operation and accuracy. The information is noted in the electronic spreadsheets and in the log books.

Procedures are available in the operations and maintenance manual for the calibration of the continuous analyzers.

The continuous chlorine analysers are calibrated when the unit reads 5% above or below in-house titration results. Records of each calibration are made in the daily log book and the maintenance log book at the treatment plant. Handheld colorimeters are verified against titration tests on a weekly basis, and the hand held unit is used to verify the calibration of the analyzers at the reservoirs.

The turbidity and pH meters are calibrated on a monthly frequency and a record is made in the daily log book and the maintenance log book at the treatment plant.

### OPERATIONS MANUALS

- \* **The operations and maintenance manuals contained plans, drawings and process descriptions sufficient for the safe and efficient operation of the system.**

An operations and maintenance manual has been created and is available on-site for the utility operator's use at the Huntsville (Fairview) water treatment plant. The manual was updated in 2014 to reflect changes to the works and the contents of the manual appear to be sufficient, enabling staff to safely operate the drinking water system. The manual had not yet been updated to reflect the new Trent Severn Gas Chlorinators which were installed recently, however the equipment manuals are available on site, and plans are to have the operations manual updated to reflect those new components.

- \* **The operations and maintenance manuals did meet the requirements of the Permit and Licence or Approval issued under Part V of the SDWA.**

Condition 16, Schedule B of the Licence prescribes that the Huntsville (Fairview) drinking water system operations and maintenance manual include at a minimum:

- the requirements of the licence and associated procedures;
- the requirements of the drinking water works permit for the drinking water system;
- procedures for monitoring and recording the in-process parameters necessary for the control of any treatment subsystem and for assessing the performance of the drinking water system;
- procedures for the operation and maintenance of monitoring equipment;
- contingency plans and procedures for the provision of adequate equipment and material to deal with emergencies, upset conditions and equipment breakdown; and,
- procedures for the dealing with complaints related to the drinking water system, including the recording of the nature of the complaint and any investigation and corrective action taken in respect of the complaint.

Procedures necessary for the operation and maintenance of any alterations to the drinking water system must also be incorporated into the operations and maintenance manual prior to the alterations coming into operation.

The operations manual and the contingency plans for the drinking water system appear to address all of these topics sufficiently, providing the utility operators enough information to effectively operate the drinking water system. As previously discussed, plans are in place to update the manuals to reflect the new Trent Severn Gas Chlorinators installed in 2015.

### LOGBOOKS

- \* **Records or other record keeping mechanisms confirmed that operational testing not performed by continuous monitoring equipment was being done by a certified operator, water quality analyst, or person who suffices the requirements of O. Reg. 170/03 7-5.**

Records reviewed indicate that only the certified utility operators are the individuals that are performing the operational tests throughout the system.

### SECURITY

- \* **The owner had provided security measures to protect components of the drinking-water system.**

Security measures in place throughout the Huntsville (Fairview) drinking water system include fencing, locked gates, secure entrance doors and security systems. The security alarms utilized are connected to the SCADA system. The on call operator is alerted to an alarm condition, must acknowledge it, and determine the appropriate response to the situation.

The owner reported no concerns with security or vandalism over the inspection review period.

### CERTIFICATION AND TRAINING

### CERTIFICATION AND TRAINING

- **The overall responsible operator had been designated for each subsystem.**

In accordance with Ontario Regulation 128/04 (Certification of Drinking Water System Operators and Water Quality Analysts) made under the SDWA, the "Huntsville Highway 60 Water Treatment Plant" is classified as a Class 3 Water Treatment Subsystem (#939 issued September 6, 2005) while the "Huntsville Water Distribution System" is classified as a Class 3 Water Distribution Subsystem (#942 issued May 25, 2005).

At the time of this inspection, individuals possessing Class 4 Water Treatment Subsystem and Class 3 Water Distribution certificates, at a minimum, have been designated to act in the capacity of Overall Responsible Operator (ORO). Other operators, who possess, at a minimum, Class 3 Water Treatment and Distribution certification, are also available and may serve in the ORO capacity, if required.

Records identifying the name of the individual serving in the capacity of ORO is documented within facility logbooks on a daily basis. There were no records to indicate that individuals other than sufficiently certified operators were acting in the capacity of ORO during this inspection review period.

The water treatment plant and operator certificates are prominently displayed at the Fairyview water treatment plant and the distribution and lines crew certificates are posted at the Chaffey Street Lines Shop.

- **Operators in charge had been designated for all subsystems which comprised the drinking-water system.**

The Owner has designated the operators who possess the appropriate level of certification to act as Operator-in-Charge (OIC) as required. Typically, the operator doing facility checks is considered the OIC of the facility on that particular day.

- **Only certified operators made adjustments to the treatment equipment.**

Records provided for review indicate that the District of Muskoka utility operators appear to be the only persons who are adjusting water treatment equipment and processes at the water treatment plant.

### WATER QUALITY MONITORING

- **All microbiological water quality monitoring requirements for distribution samples were being met.**

The owner of a large municipal residential drinking water system shall ensure that if the system serves a population of 100,000 or less, at least 8 distribution samples plus one for every thousand people served by the system are taken every month. At least one of the samples must be taken each week. As Huntsville's population is estimated to be 9000 residents, 17 samples must be collected monthly as a minimum requirement from the distribution system. These samples are required to be tested for E.Coli. and total coliform; and at least 25 percent of the samples are required to be tested for general bacteria populations expressed as colony counts on a heterotrophic plate count.

A review of the data supplied by the Owner indicates that the owner is routinely collecting a minimum of five to six distribution samples each week in order to comply with, and exceed, the regulatory requirement. Each of those samples were tested for E.Coli., total coliform, and approximately 25 to 30% of the samples were tested for general bacteria populations expressed as colony counts on a heterotrophic plate count.

The results of microbiological sampling are discussed in more detail in a later section of this inspection report.

**WATER QUALITY MONITORING**

- \* **All microbiological water quality monitoring requirements for treated samples were being met.**

Section 10-3 of Schedule 10, O.Reg.170/03 requires the Owner to ensure samples are collected at least once every week from the system's treated water at the point of entry into the distribution system. The samples collected are required to be tested for E.Coli and total coliform, and general bacteria populations expressed as colony counts on a heterotrophic plate count.

Records reviewed in the course of this inspection indicate that the Owner complied with these requirements.

- \* **All inorganic water quality monitoring requirements prescribed by legislation were conducted within the required frequency.**

Section 13-2 of Schedule 13, O.Reg.170/03 requires the Owner and the operating authority to ensure that at least one water sample is taken every 12 months if the system obtains water from a raw water supply that is surface water, and have those samples tested for every inorganic parameter set out in Schedule 23, O.Reg.170/03.

Complying with these requirements, the Owner last conducted this sampling on April 13, 2015. Prior to that, this sampling was last conducted on April 14, 2014. There were no concerns identified with the results obtained.

- \* **All organic water quality monitoring requirements prescribed by legislation were conducted within the required frequency.**

Section 13-4 of Schedule 13, O.Reg.170/03 requires the Owner and the operating authority to ensure that at least one water sample is taken every 12 months if the system obtains water from a raw water supply that is surface water, and have those samples tested for every organic parameter set out in Schedule 24, O.Reg.170/03.

Complying with these requirements, the Owner last conducted this sampling on April 13, 2015. Prior to that, this sampling was last conducted April 14, 2014. There were no concerns identified with the results obtained.

- \* **All trihalomethanes water quality monitoring requirements prescribed by legislation were conducted within the required frequency.**

Section 13-6 of Schedule 13, O.Reg.170/03 requires the Owner and the operating authority to ensure that at least one distribution sample is taken every 3 months from a point in the drinking water system's distribution system, or in plumbing that is connected to the drinking water system, that is likely to have an elevated potential for the formation of Trihalomethanes (THMs), and tested for THMs. Section 6-1.1 of Schedule 6, O.Reg.170/03 requires that these samples be taken at least 60 days, and not more than 120 days, after a sample was taken for that purpose in the previous three month period.

Complying with these requirements, the Owner conducted this quarterly sampling July 2, 2014; October 20, 2014; January 12, 2015; April 13, 2015 and July 13, 2015. In addition, THM sampling is currently being conducted every month at various locations throughout the distributions system. This additional monitoring is being conducted in conjunction with changes which have been made with the chlorine addition processes at the water treatment plant and adjustments which have been made at the reservoirs and within the distribution system. The changes and additional monitoring has been implemented in efforts of reducing THM formation through the treatment process and throughout the distribution system. The changes at the plant have included adjustment to the chlorine dosage rates within and through the plant and improvements in the control of the trim chlorine injection. Reservoir levels and valve changes within the distribution system have also occurred in efforts of reducing the age of water within the distribution system, keeping the water fresher and significantly lowering the level of THM formation within the distribution system.

THM results during this inspection review period ranged between 37 to 103 micrograms per Litre (ug/L). The running annual average of the four most recent samples collected is 69ug/L, below the Ontario Drinking Water Quality Standard of 100ug/L.

**WATER QUALITY MONITORING**

- \* **All nitrate/nitrite water quality monitoring requirements prescribed by legislation were conducted within the required frequency for the DWS.**

Section 13-7 of Schedule 13, O.Reg.170/03 requires the Owner to ensure that at least one water sample is taken every three months and tested for nitrates and nitrites. Section 6-1.1 of Schedule 6, O.Reg.170/03 requires that these samples be taken at least 60 days, and not more than 120 days, after a sample was taken for that purpose in the previous three month period.

Complying with these requirements, the Owner conducted this required monitoring on July 2, 2014; October 20, 2014; January 12, 2015; April 13, 2015 and July 13, 2015. There were no concerns identified with the results obtained.

- \* **All sodium water quality monitoring requirements prescribed by legislation were conducted within the required frequency.**

Section 13-8 of Schedule 13, O.Reg.170/03 requires the Owner to ensure that a treated water sample is taken every 60 months and is tested for sodium. Records, provided by the Owner and reviewed during the course of this inspection, indicate that the Owner conducted sampling for sodium on April 13, 2015. Prior to that, sampling for sodium had been undertaken April 14, 2014.

Results of Sodium sampling are discussed in more detail in a later section of this inspection report.

- \* **All fluoride water quality monitoring requirements prescribed by legislation were conducted within the required frequency.**

Section 13-9 of Schedule 13, O.Reg.170/03 requires the Owner and the operating authority to ensure that at least one water sample is taken every 60 months and tested for Fluoride, if the system does not provide fluoridation. As previously discussed, the Huntsville (Fairview) WTP had historically provided fluoridation, however this practice was stopped on February 3, 2014.

Complying with the Section 13-9 requirement, the Owner last conducted Fluoride sampling on April 13, 2015 and prior to which had conducted this sampling on April 14, 2014. The Fluoride results obtained ranged between 0.06 and 0.58mg/L, below the Ontario Drinking Water Quality Standard of 1.5 mg/L.

- \* **All sampling requirements for lead prescribed by schedule 15.1 of O. Reg. 170/03 were being met.**

Based on the results of historical lead sampling, the Owner is exempt from the requirement to sample lead within the plumbing of the private residences in the Huntsville community. Instead, the Owner must ensure to test for total alkalinity and pH during each of the prescribed sampling periods (December 15 to April 15 and June 15 and October 15), and must ensure lead is sampled within the distribution system in each of the prescribed sampling periods in every third 12 month period. Based on the population (9000) of the Huntsville community, the Owner is required to ensure this sampling is conducted from three locations within the distribution system.

The initial three year cycle commenced with the December 15, 2012 to April 15, 2013 sample period followed by the June 15, 2013 to October 15, 2013 sample period. In each of those instances, three distribution samples were obtained and there were no concerns identified from any of the results obtained. Most recently, and during this inspection review period, sampling for lead occurred from three locations within the distribution system on February 3, 2015. The Lead results ranged between 0.02 and 0.70ug/L, well within the Ontario Drinking Water Quality Standard of 10ug/L. While, Alkalinity results ranged between 26 and 52mg/L and pH ranged between 6.79 and 7.88.

Alkalinity and pH sampling is also undertaken on a weekly basis as part of the Langelier Saturation Index(LSI) sampling implemented by the Owner.



**WATER QUALITY MONITORING**

- \* **Records confirmed that chlorine residual tests were being conducted at the same time and at the same location that microbiological samples were obtained.**

Subsection 6-3 (1) of Schedule 6 of O.Reg.170/03 prescribes that if a microbiological sample required by the regulation is taken, that another sample must be taken at the same time from the same location and tested immediately for free chlorine residual. Records reviewed during the course of this inspection indicate that the Owner ensured that a free chlorine residual was taken at the time of all microbiological samples. Operational staff recorded the free available chlorine residual tests directly on the Laboratory Sample Submission / Chain of Custody Form at the same time that microbiological samples were obtained. The chlorine residuals associated with microbiological sample were then included by the laboratory on the analytical report associated with results of the microbiological test.

**WATER QUALITY ASSESSMENT**

- \* **The audit samples collected by the inspector met the applicable Ontario Drinking Water Quality Standards and/or the aesthetic objectives or operation guidelines. The results of the audit sampling are summarized as follows:**

The inspecting Provincial Officer conducted an assessment of chlorine residual concentrations from three points in the distribution system as part of the inspection. The locations used were the Skyline Reservoir, the Hanes Reservoir and the Dufferin Street Reservoir. The free chlorine residual concentrations observed, ranged between 0.84 and 0.93mg/L.

Microbiological and chemical audit samples were not collected as part of this inspection.

- \* **Records show that water sample results taken during the review period met the Ontario Drinking Water Quality Standards (O. Reg. 169/03), with the following exceptions:**

1. A sample collected October 27, 2014 within the distribution system indicated the presence of Total coliform bacteria (1CFU/100ml) above the limits identified in the Ontario Drinking Water Quality Standards (ODWQS). The Owner made all appropriate notifications (AWQI#121326), and re-samples collected, October 29, 2014, showed no further indication of adverse water quality at the time of collection.

Adverse water quality notifications were also made on two other occasions during this inspection review period, however these notifications were not made as a result of a microbiological or chemical sample exceeding the ODWQS.

More specifically, a notification was made (AWQI#118160) on June 20, 2014, when a PLC failure occurred with the booster pump controls at the Dufferin Street Reservoir, causing the booster pumps to shut down for approximately 68 minutes and resulting in low water pressure in portions of the distribution system serviced by the station. The control issues were addressed and pressure was restored. The affected portions of the distribution system was flushed, confirming that adequate chlorine residuals were maintained in those areas, and microbiological samples collected following the event showed no indication of adverse water quality as a result of the occurrence. The Owner made all appropriate notifications of the event to the Ministry and the Simcoe Muskoka District Health Unit (SMDHU), and the SMDHU was reportedly satisfied with the corrective actions implemented.

The second notification was made in response to the filter effluent turbidity exceedance which occurred on May 4, 2015, which resulted in approximately 20 m3 of filtered water exceeding 1.0NTU being conveyed to the treated water reservoir. The May 4, 2015 high turbidity occurrence was the result of a SCADA control issue which occurred during some maintenance work on the coagulant chemical feed system. The incident was responded to immediately and was reported to the Ministry and the SMDHU immediately as AWQI#123465. There was no indication that the occurrence impacted on the downstream disinfection process during the occurrence and continuous monitoring records indicate that the filters were still operated to meet the performance criterion for filtered water turbidity of less than or equal to 0.3 NTU in 95% of the measurements

**WATER QUALITY ASSESSMENT**

during the month of May. Following the event, additional changes were also made to the SCADA filter backwash controls to ensure similar occurrences are not repeated. The Owner made all appropriate notifications of the event to the Ministry and the SMDHU, and the SMDHU was reportedly satisfied with the corrective actions implemented.

Aside from these occurrences, there were no other adverse water quality events identified during this inspection review period.

Prior to this inspection review period, a sample collected on April 12, 2013 did indicate a slightly elevated level of Sodium in the treated water, with a result of 20.4mg/L being rendered. Where the concentration of sodium exceeds 20mg/L in a drinking water sample the Owner is required to make a report in accordance with subsection 16-3(1) of Schedule 16, O.Reg.170/03; if such a report had not been made in the previous 60 months. The Owner made the appropriate notification for the April 12, 2013 test result (AWQI 110511) and resamples collected did not confirm the elevated sodium result with a concentration of 12.5mg/L being rendered and reported to the SMDHU. Similarly, sampling for sodium conducted on April 14, 2015 (16.6mg/L) and again on April 13, 2015 (18.5mg/L) have not indicated elevated levels of sodium.

**REPORTING & CORRECTIVE ACTIONS**

- \* **Corrective actions (as per Schedule 17) had been taken to address adverse conditions, including any other steps that were directed by the Medical Officer of Health.**
  
- \* **All required notifications of adverse water quality incidents were immediately provided as per O. Reg. 170/03 16-6.**
  
- \* **Where required continuous monitoring equipment used for the monitoring of chlorine residual and/or turbidity triggered an alarm or an automatic shut-off, a qualified person responded in a timely manner and took appropriate actions.**

Following a review of the SCADA and the log book entries for the inspection review period, where required, operators responded to and took appropriate measures where necessary, in response to alarm conditions. Explanations appear to have been consistently provided for power interruptions, maintenance activities and any communication errors that triggered alarms. No concerns were identified.

**NON-COMPLIANCE WITH REGULATORY REQUIREMENTS AND ACTIONS REQUIRED**

This section provides a summary of all non-compliance with regulatory requirements identified during the inspection period, as well as actions required to address these issues. Further details pertaining to these items can be found in the body of the inspection report.

Not Applicable

**SUMMARY OF RECOMMENDATIONS AND BEST PRACTICE ISSUES**

This section provides a summary of all recommendations and best practice issues identified during the inspection period. Details pertaining to these items can be found in the body of the inspection report. In the interest of continuous improvement in the interim, it is recommended that owners and operators develop an awareness of the following issues and consider measures to address them.


Not Applicable

**SIGNATURES**

Inspected By:

James Crumbie


Signature: (Provincial Officer):



Reviewed &amp; Approved By:

Craig Seabrook

Signature: (Supervisor):



Review &amp; Approval Date:

2015-08-19

Note: This inspection does not in any way suggest that there is or has been compliance with applicable legislation and regulations as they apply or may apply to this facility. It is, and remains, the responsibility of the owner and/or operating authority to ensure compliance with all applicable legislative and regulatory requirements.



---

**Stakeholder Appendix**


---

# Key Reference and Guidance Material for Municipal Residential Drinking Water Systems

Many useful materials are posted on the Ministry of the Environment's Drinking Water Ontario website at [www.ontario.ca/drinkingwater](http://www.ontario.ca/drinkingwater) to help in the operation of your drinking water system.

Below is a list of key materials frequently used by owners and operators of municipal drinking water systems. To read or download these materials, go to **Drinking Water Ontario** and search in the **Resources** section by **Publication Number**.

Visit **Drinking Water Ontario** for more useful materials. Contact the Public Information Centre if you need assistance or have questions at 1-800-565-4923/416-325-4000 or [picemail.moe@ontario.ca](mailto:picemail.moe@ontario.ca).



PUBLICATION NUMBER	PUBLICATION TITLE
4448e01	Procedure for Disinfection of Drinking Water in Ontario
7152e	Strategies for Minimizing the Disinfection Products Trihalomethanes and Haloacetic Acids
7467	Filtration Processes Technical Bulletin
7685	Ultraviolet Disinfection Technical Bulletin
8215	Total Trihalomethane (TTHM) Reporting Requirements Technical Bulletin (February 2011)
2601e	Overview Guide: Municipal Drinking Water Licensing Program
0000	Municipal Drinking Water Licensing Program Bulletin, Issue 1, January 2011
0000	Certification Guide for Operators and Water Quality Analysts
6560e	Taking Samples for the Community Lead Testing Program
7423e	Community Sampling and Testing for Lead: Standard and Reduced Sampling and Eligibility for Exemption
7128e	Drinking Water System Contact List
4449e01	Technical Support Document for Ontario Drinking Water Quality Standards


[ontario.ca/drinkingwater](http://ontario.ca/drinkingwater)

# Principaux guides et documents de référence sur les réseaux résidentiels municipaux d'eau potable

Beaucoup de documentation sur le fonctionnement d'un réseau d'eau potable se trouve sur le site Web du ministère de l'Environnement.

Vous trouverez ci-dessous la liste des principaux documents que les propriétaires et les exploitants de réseaux municipaux d'eau potable utilisent fréquemment. Pour lire ou télécharger ces documents, allez sur le site Web du Ministère, et effectuez une recherche par numéro de publication dans la section RESSOURCES.

Consultez le site d'Eau potable Ontario pour obtenir d'autre documentation. Communiquez avec le Centre d'information du public au 1 800 565-4923



ou au 416 325-4000, ou encore à [picemail.moe@ontario.ca](mailto:picemail.moe@ontario.ca) si vous avez des questions ou besoin d'aide.

<b>NUMÉRO DE PUBLICATION</b>	<b>TITRE DE LA PUBLICATION</b>
4448f01	Marche à suivre pour désinfecter l'eau potable en Ontario
7152e	Strategies for Minimizing the Disinfection Products Trihalomethanes and Haloacetic Acids (en anglais seulement)
7467	Filtration Processes Technical Bulletin (en anglais seulement)
7685	Ultraviolet Disinfection Technical Bulletin (en anglais seulement)
8215	Total Trihalomethane (TTHM) Reporting Requirements Technical Bulletin (février 2011) (en anglais seulement)
2601f	Guide général - Programme de délivrance des permis de réseaux municipaux d'eau potable
0000	Bulletin du Programme des permis de réseaux municipaux d'eau potable, numéro 1, janvier 2011
0000	Guide sur l'accréditation des exploitants de réseaux d'eau potable et des analystes de la qualité de l'eau de réseaux d'eau potable
6560f	Prélèvement d'échantillons dans le cadre du programme d'analyse de la teneur en plomb de l'eau dans les collectivités
7423f	Échantillonnage et analyse du plomb dans les collectivités : échantillonnage normalisé ou réduit et admissibilité à l'exemption
7128f	Liste des personnes-ressources du réseau d'eau potable
4449f01	Document d'aide technique pour les normes, directives et objectifs associés à la qualité de l'eau potable en Ontario

[ontario.ca/drinkingwater](http://ontario.ca/drinkingwater)





---

**MOE Audit Sample Results**

---

Not Applicable



---

**Provincial Officer's Report & Order**

---

Not Applicable



---

**Inspection Rating Record**

---

Ministry of the Environment - Inspection Summary Rating Record (Reporting Year - 2015-2016)

**DWS Name:** HUNTSVILLE (FAIRYVIEW) DRINKING WATER SYSTEM  
**DWS Number:** 220002093  
**DWS Owner:** Muskoka, The Corporation Of The District Municipality Of  
**Municipal Location:** Huntsville

**Regulation:** O.REG 170/03  
**Category:** Large Municipal Residential System  
**Type Of Inspection:** Focused  
**Inspection Date:** August 6, 2015  
**Ministry Office:** Barrie District

Maximum Question Rating: 496

Inspection Module	Non-Compliance Rating
Capacity Assessment	0 / 30
Treatment Processes	0 / 85
Operations Manuals	0 / 28
Logbooks	0 / 14
Certification and Training	0 / 28
Water Quality Monitoring	0 / 112
Reporting & Corrective Actions	0 / 66
Treatment Process Monitoring	0 / 133
<b>TOTAL</b>	<b>0 / 496</b>

Inspection Risk Rating | 0.00%

**FINAL INSPECTION RATING: 100.00%**

Ministry of the Environment - Detailed Inspection Rating Record (Reporting Year - 2015-2016)

**DWS Name:** HUNTSVILLE (FAIRYVIEW) DRINKING WATER SYSTEM  
**DWS Number:** 220002093  
**DWS Owner:** Muskoka, The Corporation Of The District Municipality Of  
**Municipal Location:** Huntsville

**Regulation:** O.REG 170/03  
**Category:** Large Municipal Residential System  
**Type Of Inspection:** Focused  
**Inspection Date:** August 6, 2015  
**Ministry Office:** Barrie District

**Maximum Question Rating:** 496

**Inspection Risk Rating** 0.00%

**FINAL INSPECTION RATING:** 100.00%