



OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	220002093
Drinking-Water System Name:	Huntsville Potable Water Plant
Drinking-Water System Owner:	District Municipality of Muskoka
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 01 to December 31, 2022

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>District Municipality of Muskoka 70 Pine Street Bracebridge, Ontario P1L 1N3 (705) 645-6764 www.muskoka.on.ca</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text" value="N/A"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes <input type="checkbox"/> No <input type="checkbox"/></p> <p>Number of Interested Authorities you report to: <input type="text" value="N/A"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes <input type="checkbox"/> No <input type="checkbox"/></p>
---	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes No

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
 Public access/notice via Government Office
 Public access/notice via a newspaper
 Public access/notice via Public Request
 Public access/notice via a Public Library
 Public access/notice via other method _____

Describe your Drinking-Water System

The Water Treatment Plant serving the Town of Huntsville was constructed in 1988. The treatment process consists of chemically assisted coagulation-flocculation, sedimentation, filtration, disinfection by chlorination and pH adjustment. The capacity of the plant is 9000 cubic meters per day. The water source is Fairy Lake, a fairly large and clear body of water. The intake is located in 15 meters of water, about 280 meters from shore.

List all water treatment chemicals used over this reporting period

Sodium HypoChlorite, Polyaluminum Chloride, Soda Ash

Were any significant expenses incurred to?

- Install required equipment
 Repair required equipment
 Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

There were no major monetary expenses incurred in the 2022 reporting period at this facility.

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	52	0 - 4	0 - 49	0	~
Treated	52	0 - 0	0 - 0	52	0 - 3
Distribution	257	0 - 0	0 - 0	85	0 - 1



Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Geomean
Turbidity	8760	0.06 – 0.18 NTU	0.08 NTU
Chlorine	8760	1.01 – 1.91 mg/L	1.61 mg/L
Fluoride (If the DWS provides fluoridation)	Not in use	Not in use	Not in use

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	May 02, 2022	0.6<MDL	µg/L	No
Arsenic	May 02, 2022	0.2<MDL	µg/L	No
Barium	May 02, 2022	12.2	µg/L	No
Boron	May 02, 2022	7	µg/L	No
Cadmium	May 02, 2022	0.004	µg/L	No
Chromium	May 02, 2022	0.20	µg/L	No
*Lead				
Mercury	May 02, 2022	0.01<MDL	µg/L	No
Selenium	May 02, 2022	0.04<MDL	µg/L	No
Sodium	May 02, 2022	16.1	mg/L	No
Uranium	May 02, 2022	0.002<MDL	µg/L	No
Fluoride	May 02, 2022	0.06<MDL	mg/L	No
Nitrite	Feb 07, 2022	0.003<MDL	mg/L	No
Nitrate	Feb 07, 2022	0.273	mg/L	No
Nitrite	May 02, 2022	0.003<MDL	mg/L	No
Nitrate	May 02, 2022	0.284	mg/L	No
Nitrite	Aug 02, 2022	0.003<MDL	mg/L	No
Nitrate	Aug 02, 2022	0.347	mg/L	No
Nitrite	Nov 07, 2022	0.003<MDL	mg/L	No
Nitrate	Nov 07, 2022	0.222	mg/L	No

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems



Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing				
Distribution	6	0.01 – 0.99	µg/L	0

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	May 02, 2022	0.02<MDL	µg/L	No
Atrazine + N-dealkylated metabolites	May 02, 2022	0.01<MDL	µg/L	No
Azinphos-methyl	May 02, 2022	0.05<MDL	µg/L	No
Benzene	May 02, 2022	0.32<MDL	µg/L	No
Benzo(a)pyrene	May 02, 2022	0.004<MDL	µg/L	No
Bromoxynil	May 02, 2022	0.33<MDL	µg/L	No
Carbaryl	May 02, 2022	0.05<MDL	µg/L	No
Carbofuran	May 02, 2022	0.01<MDL	µg/L	No
Carbon Tetrachloride	May 02, 2022	0.17<MDL	µg/L	No
Chlorpyrifos	May 02, 2022	0.02<MDL	µg/L	No
Diazinon	May 02, 2022	0.02<MDL	µg/L	No
Dicamba	May 02, 2022	0.20<MDL	µg/L	No
1,2-Dichlorobenzene	May 02, 2022	0.41<MDL	µg/L	No
1,4-Dichlorobenzene	May 02, 2022	0.36<MDL	µg/L	No
1,2-Dichloroethane	May 02, 2022	0.35<MDL	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	May 02, 2022	0.33<MDL	µg/L	No
Dichloromethane	May 02, 2022	0.35<MDL	µg/L	No
2-4 Dichlorophenol	May 02, 2022	0.15<MDL	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	May 02, 2022	0.19<MDL	µg/L	No
Diclofop-methyl	May 02, 2022	0.40<MDL	µg/L	No
Dimethoate	May 02, 2022	0.06<MDL	µg/L	No
Diquat	May 02, 2022	1<MDL	µg/L	No
Diuron	May 02, 2022	0.03<MDL	µg/L	No
Glyphosate	May 02, 2022	1<MDL	µg/L	No
Malathion	May 02, 2022	0.02<MDL	µg/L	No
MCPA	May 02, 2022	0.00012<MDL	µg/L	No
Metolachlor	May 02, 2022	0.01<MDL	µg/L	No
Metribuzin	May 02, 2022	0.02<MDL	µg/L	No
Monochlorobenzene	May 02, 2022	0.30<MDL	µg/L	No
Paraquat	May 02, 2022	1<MDL	µg/L	No
Pentachlorophenol	May 02, 2022	0.15<MDL	µg/L	No
Phorate	May 02, 2022	0.01<MDL	µg/L	No
Picloram	May 02, 2022	1<MDL	µg/L	No
Polychlorinated Biphenyls(PCB)	May 02, 2022	0.04<MDL	µg/L	No



Prometryne	May 02, 2022	0.03<MDL	µg/L	No
Simazine	May 02, 2022	0.01<MDL	µg/L	No
THM (NOTE: annual average from Distribution – 8 samples)	Samples Taken: Feb. 07, 2022 May 02, 2022 Aug 02, 2022 Nov 07, 2022	33.8	µg/L	No
Terbufos	May 02, 2022	0.01<MDL	µg/L	No
Tetrachloroethylene	May 02, 2022	0.35<MDL	µg/L	No
2,3,4,6-Tetrachlorophenol	May 02, 2022	0.20<MDL	µg/L	No
Triallate	May 02, 2022	0.01<MDL	µg/L	No
Trichloroethylene	May 02, 2022	0.44<MDL	µg/L	No
2,4,6-Trichlorophenol	May 02, 2022	0.25<MDL	µg/L	No
Trifluralin	May 02, 2022	0.02<MDL	µg/L	No
Vinyl Chloride	May 02, 2022	0.17<MDL	µg/L	No
HAA5 (Distribution Water)	Samples Taken:			
	Feb 07, 2022	45.7	µg/L	No
	May 02, 2022	43.1	µg/L	No
	Aug 02, 2022	47.0	µg/L	No
	Nov 07, 2022	44.0	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Distribution HAA5	45.0	µg/L	RAA of quarterly results
Distribution THM	55.7	µg/L	RAA of quarterly results