



OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	260071435
Drinking-Water System Name:	Birch Glen Potable Water Plant
Drinking-Water System Owner:	District Municipality of Muskoka
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 01 to December 31, 2023

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>District Municipality of Muskoka 70 Pine Street Bracebridge, Ontario P1L 1N3 (705) 645-6764 www.muskoka.on.ca</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No [x]</p>
---	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [] No []



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

The water treatment plant servicing the village of Baysville was commissioned July 2006. The treatment process consists of chemically assisted coagulation-flocculation, sedimentation, filtration, and disinfection by chlorination and pH adjustment. The capacity of the plant is 1,100 cubic meters per day. The water source is Lake of Bays. The intake is located about 385 meters offshore.

List all water treatment chemicals used over this reporting period

Hydrated Lime, Sodium Hypochlorite, Carbon Dioxide, Sodium Hydroxide and Polyaluminum Chloride. Fluoride discontinued in January 2014.

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

N/A

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.



	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	52	0 - 4	0 - 55	n/a	~
Treated	52	0 - 0	0 - 0	52	0 - 1
Distribution	153	0 - 0	0 - 0	52	0 - 3

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Geomean
Turbidity	8760	0.06 – 0.29	0.13 NTU
Chlorine	8760	1.00 – 2.09 mg/L	1.46 mg/L
Fluoride (If the DWS provides fluoridation)	Not in Use		

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	May 01, 2023	0.6<MDL	µg/L	No
Arsenic	May 01, 2023	0.2<MDL	µg/L	No
Barium	May 01, 2023	11.3	µg/L	No
Boron	May 01, 2023	4	µg/L	No
Cadmium	May 01, 2023	0.010	µg/L	No
Chromium	May 01, 2023	0.11	µg/L	No
*Lead				
Mercury	May 01, 2023	0.01<MDL	µg/L	No
Selenium	May 01, 2023	0.04<MDL	µg/L	No
Sodium	May 01, 2023	5.56	mg/L	No
Uranium	May 01, 2023	0.003	µg/L	No
Fluoride	May 01, 2023	0.06<MDL	mg/L	No
Nitrite	Feb 06, 2023	0.003<MDL	mg/L	No
Nitrate	Feb 06, 2023	0.140	mg/L	No
Nitrite	May 01, 2023	0.003<MDL	mg/L	No
Nitrate	May 01, 2023	0.155	mg/L	No
Nitrite	Aug 14, 2023	0.003<MDL	mg/L	No
Nitrate	Aug 14, 2023	0.025	mg/L	No

Nitrite	Nov 13, 2023	0.003<MDL	mg/L	No
Nitrate	Nov 13, 2023	0.095	mg/L	No

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing				
Distribution	2	0.02 – 0.24	µg/L	0

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	May 01, 2023	0.02<MDL	µg/L	No
Atrazine + N-dealkylated metabolites	May 01, 2023	0.01<MDL	µg/L	No
Azinphos-methyl	May 01, 2023	0.05<MDL	µg/L	No
Benzene	May 01, 2023	0.32<MDL	µg/L	No
Benzo(a)pyrene	May 01, 2023	0.004<MDL	µg/L	No
Bromoxynil	May 01, 2023	0.33<MDL	µg/L	No
Carbaryl	May 01, 2023	0.05<MDL	µg/L	No
Carbofuran	May 01, 2023	0.01<MDL	µg/L	No
Carbon Tetrachloride	May 01, 2023	0.17<MDL	µg/L	No
Chlorpyrifos	May 01, 2023	0.02<MDL	µg/L	No
Diazinon	May 01, 2023	0.02<MDL	µg/L	No
Dicamba	May 01, 2023	0.20<MDL	µg/L	No
1,2-Dichlorobenzene	May 01, 2023	0.41<MDL	µg/L	No
1,4-Dichlorobenzene	May 01, 2023	0.36<MDL	µg/L	No
1,2-Dichloroethane	May 01, 2023	0.35<MDL	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	May 01, 2023	0.33<MDL	µg/L	No
Dichloromethane	May 01, 2023	0.35<MDL	µg/L	No
2-4 Dichlorophenol	May 01, 2023	0.15<MDL	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	May 01, 2023	0.19<MDL	µg/L	No
Diclofop-methyl	May 01, 2023	0.40<MDL	µg/L	No
Dimethoate	May 01, 2023	0.06<MDL	µg/L	No
Diquat	May 01, 2023	1<MDL	µg/L	No
Diuron	May 01, 2023	0.03<MDL	µg/L	No
Glyphosate	May 01, 2023	1<MDL	µg/L	No
Malathion	May 01, 2023	0.02<MDL	µg/L	No
MCPA	May 01, 2023	0.00012<MDL	µg/L	No
Metolachlor	May 01, 2023	0.01<MDL	µg/L	No

Metribuzin	May 01, 2023	0.02<MDL	µg/L	No
Monochlorobenzene	May 01, 2023	0.30<MDL	µg/L	No
Paraquat	May 01, 2023	1<MDL	µg/L	No
Pentachlorophenol	May 01, 2023	0.15<MDL	µg/L	No
Phorate	May 01, 2023	0.01<MDL	µg/L	No
Picloram	May 01, 2023	1<MDL	µg/L	No
Polychlorinated Biphenyls(PCB)	May 01, 2023	0.04<MDL	µg/L	No
Prometryne	May 01, 2023	0.03<MDL	µg/L	No
Simazine	May 01, 2023	0.01<MDL	µg/L	No
THM (NOTE: annual average from Distribution – 8 samples)	Samples Taken: Feb 06, 2023 May 01, 2023 Aug 14, 2023 Nov 13, 2023	69	µg/L	No
Terbufos	May 01, 2023	0.01<MDL	µg/L	No
Tetrachloroethylene	May 01, 2023	0.35<MDL	µg/L	No
2,3,4,6-Tetrachlorophenol	May 01, 2023	0.20<MDL	µg/L	No
Triallate	May 01, 2023	0.01<MDL	µg/L	No
Trichloroethylene	May 01, 2023	0.44<MDL	µg/L	No
2,4,6-Trichlorophenol	May 01, 2023	0.25<MDL	µg/L	No
Trifluralin	May 01, 2023	0.02<MDL	µg/L	No
Vinyl Chloride	May 01, 2023	0.17<MDL	µg/L	No
HAA5	Samples Taken: Feb 06, 2023 May 01, 2023 Aug 14, 2023 Nov 13, 2023	62.15	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Distribution THM	69	µg/L	RAA of quarterly results
Distribution HAA5	62.15	µg/L	RAA of quarterly results