



OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	220001888
Drinking-Water System Name:	Minto Water Treatment Plant
Drinking-Water System Owner:	District Municipality of Muskoka
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 01 to December 31, 2023

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>District Municipality of Muskoka 70 Pine Street Bracebridge, Ontario P1L 1N3 (705) 645-6764 www.muskoka.on.ca</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No [x]</p>
---	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [] No []



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

The water treatment plant serving the community of Bala was constructed in 1994. The treatment process consists of chemically assisted coagulation-flocculation, sedimentation and filtration using multi-media filters with a combination of gravel, sand and anthracite coal. Disinfection in a post-treatment chlorine contact chamber is followed by final pH adjustment and fluoridation before the treated water is pumped to our customers. Our waterworks currently serves a population of approximately 1000 persons. The rated water production capacity of the plant is 1942 cubic meters per day. Our raw water source is Lake Muskoka and the intake is located two meters above the lakebed at a depth of 18 meters and about 500 meters from shore.

List all water treatment chemicals used over this reporting period

Sodium Hypochlorite, Polyaluminum Chloride, Sodium Hydroxide, Carbon Dioxide, Hydrated Lime, Fluoride.

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

N/A

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	52	0 - 58	0 - 5	N.A.	N.A.
Treated	52	0 - 0	0 - 0	52	0 - 2
Distribution	168	0 - 0	0 - 0	117	0 - 660

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Geomean
Turbidity	8760	0.02 - 0.05 NTU	0.04 NTU
Chlorine	8760	1.61 – 2.51 mg/l	2.13 mg/l
Fluoride (If the DWS provides fluoridation)	8760	0.03 – 1.42 mg/l	0.66 mg/l

***NOTE:** For continuous monitors use 8760 as the number of samples.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	May 01/2023	0.6	µg/L	No
Arsenic	May 01/2023	0.2	µg/L	No
Barium	May 01/2023	11.3	µg/L	No
Boron	May 01/2023	5	µg/L	No
Cadmium	May 01/2023	0.014	µg/L	No
Chromium	May 01/2023	0.17	µg/L	No
*Lead			µg/L	No
Mercury	May 01/2023	0.01	µg/L	No
Selenium	May 01/2023	0.04	µg/L	No
Sodium	May 01/2023	11.2	mg/L	No
Uranium	May 01/2023	0.003	µg/L	No
Fluoride	May 01/2023	0.45	mg/L	No
Nitrite	Feb 06/2023	0.003	mg/L	No
Nitrate	Feb 06/2023	0.188	mg/L	No
Nitrite	May 01/2023	0.003	mg/L	No
Nitrate	May 01/2023	0.201	mg/L	No
Nitrite	Aug 08/2023	0.003	mg/L	No



Nitrate	Aug 08/2023	0.160	mg/L	No
Nitrite	Nov 06/2023	0.003	mg/L	No
Nitrate	Nov 06/2023	0.090	mg/L	No

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Geometric Mean Average	Unit of Measure	Number of Exceedances
Plumbing	0	N.A.	N.A.	N.A.	N.A.
Distribution	4	0.01-0.49	0.04	µg/L	No

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	May 01/2023	0.02	µg/L	No
Atrazine+N-dealkylated Metabolites	May 01/2023	0.01	µg/L	No
Azinphos-methyl	May 01/2023	0.05	µg/L	No
Benzene	May 01/2023	0.32	µg/L	No
Benzo(a)pyrene	May 01/2023	0.004	µg/L	No
Bromoxynil	May 01/2023	0.33	µg/L	No
Carbaryl	May 01/2023	0.05	µg/L	No
Carbofuran	May 01/2023	0.01	µg/L	No
Carbon Tetrachloride	May 01/2023	0.17	µg/L	No
Chorpyrifos	May 01/2023	0.02	µg/L	No
Diazinon	May 01/2023	0.02	µg/L	No
Dicamba	May 01/2023	0.2	µg/L	No
1,2 Dichlorobenzene	May 01/2023	0.41	µg/L	No
1,4 Dichlorobenzene	May 01/2023	0.36	µg/L	No
1,2 Dichloroethane	May 01/2023	0.35	µg/L	No
1,1 Dichloroethylene	May 01/2023	0.33	µg/L	No
Dichloromethane	May 01/2023	0.35	µg/L	No
2,4 Dichlorophenol	May 01/2023	0.15	µg/L	No
2,4-D	May 01/2023	0.19	µg/L	No
Diclofop-Methyl	May 01/2023	0.4	µg/L	No
Dimethoate	May 01/2023	0.06	µg/L	No
Diquat	May 01/2023	1	µg/L	No
Diuron	May 01/2023	0.03	µg/L	No
Glyphosate	May 01/2023	1	µg/L	No
Malathion	May 01/2023	0.02	µg/L	No
MCPA	May 01/2023	0.00012	µg/L	No
Metolachor	May 01/2023	0.01	µg/L	No
Metribuzin	May 01/2023	0.02	µg/L	No
Monochlorobenzene	May 01/2023	0.3	µg/L	No



Paraquat	May 01/2023	1	µg/L	No
Pentachlorophenol	May 01/2023	0.15	µg/L	No
Phorate	May 01/2023	0.01	µg/L	No
Picloram	May 01/2023	1	µg/L	No
PCB	May 01/2023	0.04	µg/L	No
Prometryne	May 01/2023	0.03	µg/L	No
Simazine	May 01/2023	0.01	µg/L	No
THM (NOTE: Annual average of 4 samples – Distribution system)	Feb 03/2023- Nov 06/2023	48.5	µg/L	No
HAA (NOTE: Annual average of 4 samples – Distribution system)	Feb 06/2023- Nov 06/2023	43.8	µg/L	No
Terbufos	May 01/2023	0.01	µg/L	No
Tetrachloroethylene	May 01/2023	0.35	µg/L	No
2,3,4,6 - Tetrachlorophenol	May 01/2023	0.20	µg/L	No
Triallate	May 01/2023	0.01	µg/L	No
Trichloroethylene	May 01/2023	0.44	µg/L	No
2,4,6,- Trichlorophenol	May 01/2023	0.25	µg/L	No
Trifluralin	May 01/2023	0.02	µg/L	No
Vinyl Chloride	May 01/2023	0.17	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Sodium	11.2	µg/L	May 01, 2023
HAA	43.8	µg/L	Annual average